




Energía Solar Térmica

Expositor: Dr. Eduardo Rincón Mejía

28 de noviembre al 02 de diciembre



CA 87




Solar Energy Pocket Reference

ISES

International
Solar Energy
Society

Villa Tannheim
Wiesentalstr 50
79115 Freiburg
Germany
www.ises.org

Christopher L. Martin, Ph.D.
D. Yogi Goswami, Ph.D.




Contents


		Photovoltaics	
Sun/earth geometric relationship	1	maximum power condition	54
Solar angles	2-3	cell voltage/current output effects	55-56
Solar time		system design	57-59
conversion, local ↔ solar	3	Water pumping, load data	60-61
sunrise/sunset	3	Wire, electrical load rating	61
Declination angle, table	4		
Equation of time, table	4	Water heating	62-64
World standard time meridians	5	common configurations	65
Sun path diagrams	6-13	load data	65
Shading		Space heating, load data	66-70
overhang and fin	14	Solar heating system evaluation, f-chart method	66-70
adjacent structure	15-16		
Solar radiation		Daylighting	
worldwide map, horizontal surface data	17	guidelines	70-71
worldwide table, horizontal surface data	18-31	sidelight sizing, lumen method	71-76
tilted surface, estimation procedure	32-36	transmissivity, window glass	73
ultraviolet component	36	skylight sizing, lumen method	77-78
Radiative properties of materials		Solar drying, configurations	79
absorptivity & emissivity of common materials	37-39	Life cycle costing	80-82
absorptivity & emissivity of selective surfaces	40	References	83-84
absorptivity, angular variation	41	Conversion factors, constants	85-86
reflectivity of reflector materials	41	ISES, history	87-88
absorption, solar radiation in water	41		
Transparent materials			
index of refraction	42		
collector cover material properties	43-44		
Thermal collector overview	45		
Non-concentrating thermal collectors			
performance parameters	46		
incidence angle modifier	46-47		
European standard parameters	48		
Concentrating thermal collectors			
performance parameters	48		
incidence factors	49		
Thermal energy storage			
formulations	50		
containment material, thermal conductivities	50		
sensible storage materials	51		
latent storage materials	52		
thermochemical storage materials	53		

Sun/Earth Geometric Relationship

Annual motion of earth around the sun.



Location of the tropics.



Solar Angle Formulations

Latitude angle, L, the angle between a line from the center of the earth to the site of interest and the equatorial plane. Values north of the equator are positive and those south are negative

Solar declination, δ, the angle between the earth-sun line (through their centers) and the plane through the equator. Declinations are positive in the northern hemisphere and negative in the southern hemisphere.

$$\delta_s = 23.45^\circ \sin\left(\frac{360(284 + n)}{365^\circ}\right)$$

Where n is the day number (Jan 1 = 1, Jan 2 = 2, etc.)

Hour angle, h_s, based on the nominal time of 24 hours for the sun to travel 360°, or 15° per hour. When the sun is due south (northern hemisphere, due north for southern hemisphere), the hour angle is 0, morning values are negative, and afternoon values are positive.

$$h_s = 15^\circ \times (\text{hours from local solar noon}) \\ = \frac{(\text{minutes from local solar noon})}{4 \text{ (min/deg)}}$$

Solar altitude angle, α, is the angle between a line collinear with the sun's rays and the horizontal plane.

$$\sin \alpha = \sin L \sin \delta_s + \cos L \cos h_s$$

Solar azimuth angle, a_s, is the angle between the projection of the earth-sun line on the horizontal plane and the due south direction (northern hemisphere) or due north (southern hemisphere).

$$a_s = \sin^{-1} \left(\frac{\cos \delta_s \sin h_s}{\cos \alpha} \right)$$

Note: a_s > 90° that is a_s (am/pm) = ±(180° - |a_s|) when:

$\{ L \leq \delta_s$
 $L > \delta_s \text{ and solar time earlier than } t_E \text{ or later than } t_W$

$$t_e/t_w = 12:00 \text{ noon} \mp (\cos^{-1}[\tan \delta_s / \tan L]) / 15 \text{ (deg/hr)}$$

Solar Time

Relation between local solar time and local standard time (LST):

$$\text{Solar Time} = \text{LST} + \text{ET} + (l_{\text{std}} - l_{\text{local}}) \times 4 \frac{\text{min}}{\text{deg}}$$

Where l_{std} is the standard time meridian, page 5, and l_{local} is the local longitude value. The equation of time, ET, can be gathered from tabular values, page 4, or computed with:

$$\text{ET (minutes)} = 9.87 \sin 2B - 7.53 \cos B - 1.5 \sin B$$

$$\text{where: } B = \frac{360(n - 81)}{364^\circ}$$

At local solar noon:

$$h_s = 0 \quad \alpha = 90^\circ - |L - \delta_s| \quad a_s = 0$$

Sunrise and Sunset Times

At sunrise or sunset the center of the sun is located at the eastern or western horizon, respectively. By definition, the altitude angle is then $\alpha = 0$. The local solar time for sunrise/sunset can be computed with:

$$\text{Sunrise/Sunset} = 12:00 \text{ noon} \mp \left[\frac{(\cos^{-1}(-\tan L \times \tan \delta_s))}{15 \text{ (deg/hour)}} \right]$$

For the tip of the sun at the horizon (apparent sunrise/sunset), subtract/add approximately 4 minutes from the sunrise/sunset times.

Values for Declination, δ_s , and Equation of Time, ET

Date	Declination			Equation of Time			Declination			Equation of Time		
	Deg	Min	Sec	Date	Deg	Min	Sec	Deg	Min	Sec	Deg	Min
Jan 1	-23	4	-3	14	Feb 1	-17	19	-13	34	2		
5	22	42	5	6	5	16	10	14	20			
9	22	13	6	30	9	14	53	14	17			
13	21	37	8	27	13	13	17	14	10			
17	20	54	9	54	17	12	13	14	10			
21	20	5	11	10	21	10	50	13	50			
25	19	9	12	14	25	9	23	11	19			
29	18	9	123	5								
Mar. 1	-7	53	-12	35	Apr 1	+4	14	-4	12			
5	6	21	11	48	5	5	46	3	1			
9	5	48	10	51	9	7	17	1	52			
13	3	14	9	49	13	8	46	-6	47			
17	1	39	8	42	17	10	12	+0	13			
21	-0	5	7	32	21	11	35	1	6			
25	+1	30	6	20	25	12	56	1	53			
29	3	4	5	7	29	14	13	2	33			
May 1	+14	50	+2	50	June 1	+21	57	2	27			
5	16	2	34	17	5	22	28	1	49			
9	17	9	3	35	9	22	52	1	6			
13	18	11	3	44	13	23	10	+0	18			
17	19	9	3	44	17	23	22	-0	13			
21	20	2	3	24	21	23	27	1	25			
25	20	49	1	16	25	23	25	2	17			
29	21	30	2	51	29	23	17	3	7			
July 1	+23	10	-1	31	Aug 1	+18	14	-6	17			
5	22	52	4	16	5	17	12	5	59			
9	22	28	4	56	9	16	6	5	33			
13	21	57	5	30	13	14	55	4	57			
17	21	24	5	57	17	13	41	4	12			
21	20	38	6	15	21	12	23	3	19			
25	19	50	6	24	25	11	2	2	18			
29	18	37	6	23	29	9	39	1	10			
Sep 1	+8	35	-0	15	Oct 1	-2	53	+10	1			
5	7	7	+1	2	5	4	26	11	17			
9	5	37	2	22	9	5	58	12	27			
13	4	6	1	45	13	7	29	11	30			
17	2	34	5	18	17	8	58	14	25			
21	1	1	6	35	21	10	25	15	10			
25	0	12	8	0	25	11	50	15	46			
29	2	6	9	22	29	13	12	16	10			
Nov 1	-14	11	+16	21	Dec 1	-21	41	11	16			
5	15	27	16	23	5	22	16	9	43			
9	16	38	16	12	9	22	45	8	1			
13	17	45	15	47	13	23	6	6	12			
17	18	48	15	10	17	23	20	4	47			
21	19	45	14	18	21	23	26	2	19			
25	20	36	13	15	25	23	25	+0	20			
29	21	21	11	59	29	23	17	-1	39			

*Since each year is 365.25 days long, the precise value of declination varies from year to year. The American Ephemeris and Nautical Almanac, published each year by the U.S. Government Printing Office, contains precise values for each day of each year.

Worldwide standard time meridians


Relative to UTC	Description	Standard Meridian, l_{st} [°]
-11	Nome Time (US) Samoa Standard Time	165° W
-10	Hawaiian Standard Time (US) Tahiti Time	150° W
-9	Alaska Standard Time (US) Yukon Standard Time	135° W
-8	US Pacific Standard Time	120° W
-7	US Mountain Standard Time	105° W
-6	US Central Standard Time Mexico Time	90° W
-5	US Eastern Standard Time Colombia Time	75° W
-4	Atlantic Standard Time Bolivia Time	60° W
-3	Eastern Brazil Standard Time Argentina Time	45° W
-2	Greenland Eastern Std. Time Fernando de Noronha Time (Brazil)	30° W
-1	Azores Time Cape Verde Time	15° W
0	Greenwich Mean Time Coordinated Universal Time Western Europe Time	0°
+1	Central Europe Time Middle European Time	15° E
+2	Eastern Europe Time Kalininograd Time (Russia)	30° E
+3	Moscow Time (Russia) Baghdad Time	45° E
+4	Volga Time (Russia) Gulf Standard Time	60° E
+5	Yekaterinburg Time (Russia) Pakistan Time	75° E
+5.5	Indian Standard Time	82.5° E
+6	Novosibirsk Time (Russia) Bangladesh Time	90° E
+7	Krasnoyarsk Time (Russia) Java Time	105° E
+8	Irkutsk Time (Russia) China Coast Time	120° E
+9	Yakutsk Time (Russia) Japan Standard Time	135° E
+10	Vladivostok Time (Russia) Guam Standard Time	150° E
+11	Magadan Time (Russia) Solomon Islands Time	165° E
±12	Kamchatka Time (Russia) New Zealand Standard Time	180°

Sun Path Diagrams

Procedure to determine the solar altitude and azimuth angles for a given latitude, time of year, and time of day:

1. **Transition the time of interest, local standard time (LST), to solar time.** See procedure page 3.
2. **Determine the declination angle based on time of year.** Use formulation page 2, or table page 4.
3. **Read the solar altitude and azimuth angles from the appropriate sun path diagram.** Diagrams are chosen based on latitude; linear interpolations are used for latitudes not covered. For values at southern latitudes change the sign of the solar declination.

Representative path diagram illustrating the determination of solar position



Note: The sign convention for the declination angle, δ_s , is for northern latitudes. To use the diagrams for southern latitudes, reverse the sign of the declination angle.

$L \leq \delta_s$
 $L > \delta_s$ and solar time earlier than t_E or later than t_W

$$t_e / t_w = 12.00 \text{ noon} \mp (\cos^{-1} [\tan \delta_s / \tan L]) / 15 \text{ (deg/hr)}$$

Solar Time

Relation between local solar time and local standard time (LST).

$$\text{Solar Time} = \text{LST} + \text{ET} + (l_{\text{st}} - l_{\text{local}}) \times 4 \frac{\text{min}}{\text{deg}}$$

Where l_{st} is the standard time meridian, page 5, and l_{local} is the local longitude value. The equation of time, ET, can be gathered from tabular values, page 4, or computed with:

$$\text{ET (minutes)} = 9.87 \sin 2B - 7.53 \cos B - 1.5 \sin B$$

$$\text{where } B = \frac{360(n-81)}{364^\circ}$$

At local solar noon.

$$h_s = 0 \quad \alpha = 90^\circ - |L - \delta_s| \quad a_s = 0$$

Sunrise and Sunset Times

At sunrise or sunset the center of the sun is located at the eastern or western horizon, respectively. By definition, the altitude angle is then: $\alpha = 0$. The local solar time for sunrise/sunset can be computed with:

$$\text{Sunrise/Sunset} = 12:00 \text{ noon} \mp \left[\frac{(\cos^{-1}(-\tan L \times \tan \delta_s))}{15 \text{ (deg/hour)}} \right]$$


For the tip of the sun at the horizon (apparent sunrise/sunset), subtract/add approximately 4 minutes from the sunrise/sunset times

Values for Declination, δ_s , and Equation of Time, ET


Date	Declination			Equation of Time			Declination			Equation of Time		
	Deg	Min	Sec	Date	Deg	Min	Sec	Deg	Min	Sec	Deg	Min
Jan. 1	-23	4	-3	14	Feb. 1	-17	19	-13	34			
5	22	42	5	6	5	16	10	14	2			
9	22	13	6	50	9	14	55	14	17			
13	21	37	8	27	13	13	37	14	20			
17	20	54	9	34	17	12	15	14	10			
21	20	5	11	10	21	10	50	13	50			
25	19	9	12	14	25	9	23	13	19			
29	18	9	123	5								
Mar. 1	-7	53	-12	38	Apr. 1	+4	14	-4	12			
5	6	21	11	48	5	5	46	3	1			
9	5	48	10	51	9	7	17	1	52			
13	3	14	9	49	13	8	46	-9	47			
17	1	39	8	42	17	10	12	+0	13			
21	-0	5	7	32	21	11	35	1	6			
25	+1	30	6	20	25	12	56	1	53			
29	3	4	5	7	29	14	13	2	33			
May 1	+14	50	+2	50	June 1	+21	57	2	27			
5	16	2	34	17	5	22	28	1	49			
9	17	9	3	35	9	22	52	1	6			
13	18	11	3	44	13	23	10	+0	18			
17	19	9	3	44	17	23	22	-0	33			
21	20	2	3	24	21	23	27	1	25			
25	20	49	3	16	25	23	25	2	17			
29	21	30	2	51	29	23	17	3	7			
July 1	+23	10	-7	31	Aug. 1	+18	14	-6	17			
5	22	52	4	16	5	17	12	5	59			
9	22	28	4	56	9	16	6	5	33			
13	21	57	5	30	13	14	55	4	57			
17	21	27	5	57	17	13	41	4	12			
21	20	38	6	15	21	12	23	3	19			
25	19	50	6	24	25	11	2	2	18			
29	18	57	6	23	29	9	39	1	10			
Sep. 1	+8	35	-0	15	Oct. 1	-2	53	+10	1			
5	7	7	+1	2	5	4	26	11	17			
9	5	37	2	22	9	5	58	12	27			
13	4	6	3	45	13	7	29	11	30			
17	2	34	5	10	17	8	58	14	25			
21	1	1	6	35	21	10	25	15	10			
25	0	32	8	0	25	11	50	15	46			
29	2	6	9	22	29	13	12	16	10			
Nov. 1	-14	31	+15	21	Dec. 1	-21	41	11	16			
5	15	27	16	23	5	22	16	9	43			
9	16	38	16	12	9	22	45	8	1			
13	17	45	15	47	13	23	6	6	12			
17	18	48	15	10	17	23	20	4	47			
21	19	45	14	18	21	23	26	2	19			
25	20	36	13	15	25	23	25	+0	20			
29	21	21	11	59	29	23	17	-1	39			

*Since each year is 365.25 days long, the precise value of declination varies from year to year. The American Ephemeris and Nautical Almanac, published each year by the U.S. Government Printing Office, contains precise values for each day of each year.


Latitude = 0°




Latitude = 10°



Latitude = 5°




Latitude = 15°




Note: The sign convention for the declination angle, δ_s , is for northern latitudes. To use the diagrams for southern latitudes, reverse the sign of the declination angle.

Note: The sign convention for the declination angle, δ_s , is for northern latitudes. To use the diagrams for southern latitudes, reverse the sign of the declination angle.


Latitude = 20°




Latitude = 30°



Latitude = 25°







Latitude = 35°



Note: The sign convention for the declination angle, δ_s , is for northern latitudes. To use the diagrams for southern latitudes, reverse the sign of the declination angle.



Note: The sign convention for the declination angle, δ_s , is for northern latitudes. To use the diagrams for southern latitudes, reverse the sign of the declination angle.




Note: The sign convention for the declination angle, δ_s , is for northern latitudes. To use the diagrams for southern latitudes, reverse the sign of the declination angle.

Note: The sign convention for the declination angle, δ_s , is for northern latitudes. To use the diagrams for southern latitudes, reverse the sign of the declination angle.

Overhang and Fin Shading Calculation



Note: The sign convention for the declination angle, δ_s , is for northern latitudes. To use the diagrams for southern latitudes, reverse the sign of the declination angle



Reprinted from [3]

For overhang shading:

$$h = \frac{D \times \tan(\text{solar altitude})}{\cos(\text{solar azimuth} - \text>window azimuth)} *$$

For fin shading:

$$w = D \times \tan(\text{solar azimuth} - \text>window azimuth) *$$


Solar altitude and azimuth angles can be determined with the sun path diagrams, beginning on page 6

* Observe proper signs for both the solar and window azimuth values. Convention is that angles east of the equator vector are negative while those west are positive

Obstruction Shading

Procedure for estimating shading caused by adjacent structures:


- Define the solid angle presented by the obstruction in terms of altitude, α_{obs} , and azimuth, a_{obs} , angles for the point of interest.** Choose characteristic points to describe the profile of the obstruction and determine their angular coordinates, refer to the geometry of the figures below and on the next page. By measuring or estimating the distances and heights in question, standard trigonometric formulas (next page) can be used to determine the angular values.
- Locate the solid angle with respect to the path of the sun.** Refer to the appropriate sun path diagram, based on the site latitude, and locate the solid angle on the diagram by plotting the α_{obs} and a_{obs} values on the solar altitude and solar azimuth axes, respectively. An example of this positioning is shown on the next page.
- Determine dates and times of shading.** On the sun path diagram, where the solid angle overlaps the declination lines, shading of the point of interest will occur. The dates can be estimated by reading the declination values that intersect the solid angle, and then matching the declination to the time of year, table page 4. In a similar manner, the hours of shading for a particular declination value, can be estimated by reading the solar time corresponding to the intersection of the declination of interest and the solid angle presented by the obstruction.





15

Obstruction Shading

Geometry for an arbitrary point Q on the profile of the obstruction



Example overlay of an obstruction profile on a sun path diagram.




16

Annual average horizontal surface insolation

July 1983 – June 1993

Source: Surface meteorology and solar energy, National Aeronautics and Space Administration, USA, <http://eosweb.larc.nasa.gov/sse>



Solar Radiation Data, [MJ/m²-day]

Position	Lat	Long	Jan.	Feb	Mar	Apr.	May	June	July	Aug	Sep.	Oct.	Nov	Dec
Argentina														
Buenos Aires	34°58'S	58°48'W	24.86	21.75	18.56	11.75	8.71	7.15	7.82	9.75	14.49	16.66	24.90	21.93
Australia														
Adelaide	34°93'S	138°52'E	20.99	17.50	20.15	18.27	17.98	—	18.81	19.64	20.11	20.88	20.57	20.72
Brisbane	27°43'S	153°08'E	25.36	22.22	13.25	16.61	12.23	11.52	9.70	15.10	17.61	19.89	—	—
Canberra	35°30'S	148°18'E	28.20	24.68	20.56	14.89	10.29	6.62	—	12.33	16.88	24.06	26.00	25.77
Darwin	12°47'S	130°63'E	26.92	23.40	18.13	13.62	9.30	7.89	9.41	11.15	14.85	18.87	23.43	22.37
Hobart	42°88'S	147°32'E	—	—	10.09	7.26	6.04	5.72	9.21	13.54	18.12	—	—	—
Laverton	37°85'S	144°08'E	22.96	20.42	15.59	13.40	7.48	6.10	6.54	10.43	13.24	18.76	—	—
Sydney	33°37'S	151°20'E	21.09	21.75	17.63	13.63	9.78	8.79	7.62	12.84	16.93	22.10	—	—
Austria														
Wien	48.20'N	16.57'E	3.54	7.10	8.05	14.72	16.79	20.87	19.89	17.27	12.55	8.45	3.51	2.82
Innsbruck	47.27'N	11.38'E	5.57	9.28	10.15	15.96	14.57	17.65	18.35	17.26	12.98	9.08	4.28	3.50
Barbados														
Husbands	13°15'N	59°62'W	19.11	20.23	—	21.80	19.84	20.86	21.55	22.14	—	—	18.30	16.56
Belgium														
Ostende	51.23'N	2.92'E	2.82	5.75	9.93	15.18	16.74	16.93	18.21	18.29	11.71	6.15	2.69	1.97
Melle	50.98'N	3.83'E	2.40	4.66	8.41	13.55	14.23	13.28	15.71	15.61	10.63	5.82	2.40	1.59
Brunici														
Brunet	4°98'N	114°93'E	19.46	20.12	22.71	20.54	19.74	18.31	19.38	20.08	20.83	17.51	17.39	18.12
Bulgaria														
Chirpan	42.20'N	25°33'E	6.72	6.79	8.54	13.27	17.25	17.39	19.85	14.61	12.53	8.52	5.08	5.09
Sofia	42.65'N	23°38'E	4.03	6.23	7.93	9.36	12.98	19.73	19.40	17.70	14.71	6.44	—	3.14
Canada														
Montreal	45.47'N	73.75'E	4.74	8.33	11.84	10.55	15.05	22.44	21.08	18.67	14.83	9.18	4.04	4.01
Ottawa	45.32'N	75.67'E	5.34	9.59	13.33	13.98	20.18	20.34	19.46	17.88	13.84	7.38	4.64	5.04
Toronto	43.67'N	79.38'E	4.79	8.15	11.96	14.00	18.16	24.35	23.38	—	15.89	9.40	4.72	3.79
Vancouver	49.18'N	123.17'E	3.73	4.81	12.14	16.41	20.65	24.04	22.87	19.08	12.77	7.39	4.29	1.53
Chile														
Pascua	27.17'S	109°43'W	19.64	16.65	—	11.12	9.52	8.81	10.90	12.29	17.19	20.51	21.20	22.44
Santiago	33.45'S	70°70'W	18.61	16.33	13.44	8.32	5.07	3.66	3.35	5.65	8.15	13.62	20.14	23.88

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Lat.	Long.	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.	
China															
Beijing	39°33' N	116°28' W	7.73	10.39	13.87	17.93	20.18	18.65	15.64	16.61	15.32	11.29	7.25	6.89	
Guangzhou	23°13' N	113°32' E	11.01	6.12	4.03	7.89	10.53	12.48	16.14	16.02	15.03	15.79	11.53	9.10	
Harbin	45°15' N	126°77' E	5.15	9.54	17.55	20.51	20.33	17.65	19.18	16.69	13.78	10.50	10.50	6.98	
Kunming	25°02' N	102°68' E	9.92	11.26	14.38	18.00	18.53	17.37	-1.95	18.47	15.94	12.45	11.96	13.62	
Lanzhou	36°05' N	103°88' E	7.30	12.47	10.62	17.40	20.40	20.23	17.37	13.23	10.21	8.22	6.43		
Shanghai	31.17' N	121°41' E	7.44	10.11	11.78	14.36	14.23	16.79	14.63	11.85	15.96	12.03	7.71	8.70	
Columbia															
Bogota	4°70' N	74°13' W	12.99	—	19.37	16.58	14.86	—	13.32	18.20	17.05	14.38	14.20	16.66	
Cuba	23°17' N	82°35' W	—	14.70	18.94	20.95	23.63	18.83	21.40	20.19	16.84	16.98	13.19	13.81	
Czech															
Kuttenbrunn	48°08' N	16.08' E	3.01	5.65	9.88	14.06	20.84	19.24	21.18	19.41	13.61	6.11	3.47	2.12	
Churakov	49°07' N	13.62' E	2.89	5.82	9.24	13.18	21.32	15.68	20.51	19.49	12.84	5.68	3.36	2.90	
Hradec-Kralov	50°25' N	15.85' E	3.51	5.94	10.58	15.95	20.42	18.43	17.17	17.92	11.86	6.27	2.45	1.89	
Denmark															
Copenhagen	55°67' N	12.30' E	1.93	3.32	7.09	11.12	21.39	—	24.93	—	13.92	10.10	5.20	2.84	1.23
Egypt															
Cairo	30°08' N	31.28' E	10.06	12.96	18.49	23.64	21.91	26.07	25.16	23.69	21.01	—	11.74	9.85	
Mena-Marsa	31.33' N	27.22' E	8.30	11.92	18.47	24.27	24.17	—	26.67	26.27	21.92	18.28	11.71	8.76	
Ehripolis															
Adulis-Alaba	3°98' N	36.80' E	—	11.39	—	12.01	—	—	—	6.33	9.35	11.71	11.69	11.50	
Fiji															
Nandi	17°55' S	177°45' E	20.82	20.65	20.25	18.81	15.68	14.10	15.08	16.71	19.37	20.11	21.78	23.09	
Savu	16°05' S	178.57' E	20.37	17.74	16.22	13.82	10.61	12.48	11.40	—	—	18.49	19.96	20.99	
Finland															
Helsinki	60°32' N	24.97' E	1.13	2.94	5.59	11.52	17.60	16.81	20.66	15.44	8.44	3.31	0.97	0.63	
France															
Agen	44°18' N	0.60' F	4.83	7.40	10.69	17.12	19.25	20.42	21.63	20.64	15.36	8.41	5.09	5.01	
Nice	43°55' N	7.20' E	6.83	—	11.37	17.70	20.74	24.10	24.85	24.86	15.04	10.99	7.08	6.73	
Paris	48°57' N	2.45' E	2.62	5.06	7.21	12.90	14.84	13.04	15.34	16.30	10.17	5.61	3.14	2.20	

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Lat.	Long.	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.
(Germany)														
Bonn	50°30' N	7.15' E	2.04	5.92	8.01	14.27	15.67	14.41	18.57	17.40	11.70	6.15	3.42	1.90
Nuremberg	33°33' N	13.20' E	3.23	6.92	9.08	15.69	15.71	13.21	21.14	17.98	12.43	8.15	2.79	2.51
Bremen	53°05' N	8.80' E	2.36	4.93	8.53	14.32	14.94	14.52	19.40	15.02	10.48	6.27	2.80	1.66
Hamburg	53°56' N	10.00' E	1.97	3.96	7.59	12.32	14.11	12.69	19.00	14.11	10.29	6.45	2.33	1.43
Suttgart	48°43' N	9.20' E	3.59	7.18	9.29	15.81	17.72	17.44	22.21	19.87	12.36	7.81	3.19	2.54
Ghana														
Accra	9.01' N	2.48' W	18.29	19.76	19.71	19.15	16.61	—	13.68	16.29	17.27	17.33	15.93	
Bole	5.60' N	0.17' W	14.82	16.26	18.27	16.73	18.15	13.96	13.86	13.49	15.32	19.14	18.16	14.33
Great Britain														
Belfast	54°45' N	6.22' W	2.06	3.69	6.85	12.90	15.41	15.09	15.46	13.56	11.49	4.63	2.34	1.24
Jersey	49°22' N	2.26' W	2.76	5.65	9.51	14.98	18.51	17.83	18.14	18.62	12.98	6.16	3.26	2.83
London	51°52' N	0.13' W	2.24	3.87	7.40	12.01	12.38	13.24	15.59	16.23	12.59	5.67	2.87	1.97
Greece														
Athens	37°57' N	23.72' E	9.11	10.94	15.70	20.91	23.85	23.48	24.21	23.08	19.03	15.29	5.98	6.64
Sikwua	37°56' N	22.73' E	7.60	8.16	11.99	21.06	22.62	24.32	23.56	21.73	17.30	11.75	9.35	6.35
Grande-Sainte-Lucie														
Le Roxel	16°27' N	61.52' W	14.88	18.10	20.55	19.59	20.26	20.65	20.65	20.24	18.47	17.79	13.49	14.38
Guyana														
Cayenne	4°43' N	52.37' W	14.46	14.67	16.28	17.57	—	14.92	17.42	18.24	20.52	—	22.69	17.04
Hong Kong														
King's Park	22°32' S	114°17' W	12.34	7.39	6.94	9.50	11.38	13.80	16.70	17.06	15.91	16.52	14.19	10.09
Hungary														
Budapest	47°43' N	19°18' E	2.61	1.46	11.14	14.46	20.69	19.47	21.45	19.72	12.88	7.96	2.95	2.47
Iceland														
Reykjavik	64°13' N	21.90' W	0.52	2.02	6.25	1.77	13.07	14.58	16.83	11.35	9.70	3.18	1.00	0.65
India														
Rishabh	19°12' N	72.85' E	18.44	21.00	22.12	24.52	24.46	19.73	15.84	16.00	18.19	20.38	19.18	17.01
Calcutta	22.53' N	88.33' E	15.69	18.34	20.09	22.34	22.37	17.35	17.07	16.55	16.52	16.90	16.35	15.00
Madras	13°00' N	80.18' E	19.69	22.71	25.14	24.88	21.89	—	18.22	19.68	19.81	16.41	14.76	15.79

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Lat	Long	Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec
India														
Nagpur	21.10 N	79.05 E	18.08	21.01	22.25	24.08	24.79	19.84	15.38	15.47	17.66	20.10	18.88	17.33
New Delhi	28.58 N	77.20 E	14.62	18.25	20.15	23.40	23.80	19.16	20.20	19.89	20.88	19.74	16.95	14.22
Ireland														
Dublin	53.43 N	6.25 W	2.51	4.75	7.48	11.06	17.46	19.11	15.64	13.89	9.65	5.77	2.93	—
Israel														
Jerusalem	31.78 N	35.22 E	10.79	13.01	18.08	23.79	29.10	31.54	31.83	28.79	25.19	20.26	12.61	10.71
Italy														
Milano	45.43 N	9.28 E	—	6.48	10.09	13.17	17.55	16.32	18.60	16.86	11.64	5.40	3.32	2.41
Rome	41.80 N	12.55 E	—	9.25	13.38	15.82	15.82	18.89	22.27	21.53	16.08	8.27	6.41	4.49
Japan														
Fukuoka	33.58 N	130.38 E	4.11	8.72	10.95	13.97	14.36	12.81	13.84	16.75	13.92	11.86	10.05	7.30
Taipei	36.05 N	140.13 E	9.06	12.17	11.00	15.78	16.52	15.26	—	—	9.60	8.55	8.26	—
Yonago	35.43 N	133.35 E	6.25	7.16	10.87	17.30	16.72	15.44	17.06	19.93	12.41	10.82	7.50	5.51
Kenya														
Mombasa	4.01 S	39.62 E	22.40	22.17	22.74	18.49	18.31	17.41	—	18.12	21.03	22.97	21.87	21.25
Nairobi	1.22 S	36.92 E	—	24.10	21.20	18.65	14.83	15.00	13.44	14.12	19.14	19.38	16.80	18.27
Lithuania														
Kaunas	54.98 N	23.88 E	1.89	4.43	7.40	12.97	18.38	18.74	21.41	15.79	10.40	5.64	1.80	1.10
Madagascar														
Anazarivo	18.80 S	47.48 E	15.94	13.18	13.07	11.53	9.25	4.21	9.32	—	—	16.43	15.19	13.62
Malaysia														
Kuala Lumpur	3.12 N	101.55 E	15.36	17.67	18.48	18.87	15.67	16.24	15.32	15.89	14.62	14.13	13.54	11.53
Hong Kong	5.30 N	100.27 E	19.47	21.35	21.24	20.52	18.63	19.32	17.17	16.96	15.93	16.07	16.35	17.37
Martinique														
Le Lamentin	14.60 N	61.00 W	17.76	20.07	22.53	21.95	22.42	21.23	20.86	21.84	20.23	19.87	14.08	16.25
Mexico														
Chiapas	23.63 N	106.08 W	14.80	—	—	—	26.94	26.28	24.01	24.22	20.25	19.55	10.57	15.79
Oaxaca	20.56 N	99.20 E	19.49	23.07	27.44	27.35	26.04	25.05	—	27.53	21.06	17.85	15.44	12.93

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Lat	Long	Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec
Mongolia														
Ulan Bator	47.92 N	106.98 E	6.28	9.22	14.34	18.18	20.50	19.34	16.34	16.65	14.08	11.36	7.19	5.35
Chasuan	47.75 N	96.65 E	6.43	10.11	14.83	20.32	23.86	20.46	21.66	17.81	15.97	10.92	7.32	5.08
Morocco														
Casablanca	33.57 N	7.67 E	11.46	12.70	15.93	21.25	24.45	25.27	25.53	23.60	19.97	14.68	11.61	9.03
Mozambique														
Maputo	25.97 S	32.60 E	23.35	23.16	19.33	20.54	16.33	14.17	—	—	—	21.55	25.48	26.19
Netherlands														
Maxenrich	50.92 N	5.78 E	3.20	5.43	8.48	14.82	14.97	14.32	18.40	17.51	11.65	6.51	3.01	1.72
New Caledonia														
Koumac	20.57 S	164.28 E	24.89	21.15	16.98	18.98	15.67	14.55	15.75	17.62	22.48	15.83	27.53	26.91
New Zealand														
Wellington	41.28 S	174.77 E	22.59	19.67	14.91	9.52	6.97	4.37	5.74	7.14	12.50	16.34	19.07	24.07
Christchurch	43.48 S	172.55 E	23.46	19.68	13.98	8.96	6.47	4.74	5.38	6.94	13.18	17.45	18.91	24.35
Nigeria														
Bauchi City	6.32 N	5.60 E	14.89	17.29	19.15	17.21	16.97	15.04	10.24	12.54	14.37	15.99	17.43	15.75
Norway														
Bergen	60.40 N	5.32 E	0.46	1.33	3.18	8.36	19.24	16.70	16.73	10.19	6.53	3.19	1.36	0.35
Oman														
Socotra	23.58 N	58.28 E	12.90	14.86	21.22	22.22	25.30	24.02	23.46	21.66	20.07	18.43	13.12	—
Sabah	17.03 N	54.08 E	16.32	16.92	18.49	20.65	21.46	16.92	8.52	11.41	17.14	18.62	16.42	—
Pakistan														
Karachi	24.90 N	67.13 E	13.84	—	—	19.69	20.31	16.62	—	—	—	—	12.94	11.07
Multan	30.20 N	71.43 E	12.29	15.86	18.33	22.35	22.57	21.65	20.31	20.44	20.57	15.91	12.68	10.00
Tirmahab	33.62 N	73.10 E	10.38	12.42	16.98	22.65	—	23.49	20.64	18.91	14.20	15.30	10.64	8.30
Peru														
Puerto	15.83 S	70.02 W	14.98	12.92	16.08	20.03	17.45	17.42	15.74	15.32	16.11	16.18	14.24	13.90
Poland														
Warszawa	52.26 N	20.97 E	1.73	3.83	7.81	10.53	19.22	17.11	20.18	15.00	10.65	4.95	2.39	1.68
Kolobrzeg	54.18 N	15.58 E	2.50	3.25	8.86	15.21	20.79	20.50	17.19	16.46	7.95	5.75	1.78	1.18

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Lat.	Long.	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.
Portugal														
Evora	38.57 N	7.90 W	9.92	12.43	17.81	18.69	23.57	29.23	28.75	23.77	20.17	—	6.81	4.57
Lisbon	38.72 N	9.13 W	9.24	11.60	17.52	18.49	24.64	29.02	28.14	22.20	19.76	13.56	7.18	4.83
Romania														
Bucuresti	44.56 N	26.13 E	7.05	10.22	12.04	16.53	18.97	22.16	23.19	17.17	9.55	4.82	—	—
Constanta	44.22 N	28.61 E	5.62	9.28	14.31	20.59	21.23	25.40	27.98	24.22	16.91	11.89	6.19	3.18
Galati	45.50 N	28.02 E	6.09	9.33	14.31	17.73	21.77	22.74	25.35	19.70	14.05	11.26	6.32	3.18
Russia														
Aleksandrovsko	60.38 N	77.87 E	1.34	4.17	9.16	17.04	21.83	21.34	20.26	13.05	10.16	4.68	1.71	0.68
Moscow	55.76 N	37.57 E	1.45	3.86	8.09	11.69	18.86	16.12	17.51	14.17	10.92	4.03	2.28	1.29
St. Petersburg	59.97 N	30.40 E	3.11	4.86	12.24	20.59	21.55	20.43	13.27	7.83	2.93	1.16	0.59	—
Vorobiov-Anok	67.55 N	13.38 E	0.21	2.25	7.61	15.96	19.64	—	—	14.12	7.59	3.51	0.54	—
St. Pierre & Miquelon	46.77 N	56.17 W	4.43	6.61	12.50	17.57	18.55	17.84	19.95	16.46	12.76	8.15	3.66	3.33
Singapore	1.37 N	101.98 E	19.08	20.94	20.75	18.20	14.89	15.22	13.92	16.66	16.51	15.82	13.81	12.67
South Korea														
Seoul	37.57 N	126.97 E	6.24	9.46	10.34	13.98	16.35	17.49	10.65	12.94	11.87	10.35	6.47	5.14
South Africa														
Cape Town	33.98 S	18.60 E	27.47	35.37	—	15.81	11.43	9.08	8.35	13.76	17.30	22.16	26.37	27.68
Pont Elizabeth	.33.98 S	25.60 E	27.22	22.06	19.01	15.29	11.79	11.13	10.73	13.97	18.52	23.09	23.15	27.26
Pretoria	25.73 S	28.18 E	26.06	22.43	20.52	16.09	15.67	13.67	15.19	18.65	21.62	21.75	24.82	23.43
Spain														
Near East	40.45 N	3.72 W	7.73	10.53	15.35	21.74	22.81	22.05	26.27	22.90	18.89	10.24	8.69	5.56
Sudan														
Wad Madani	14.40 N	33.48 E	21.92	24.01	23.43	25.17	23.92	23.51	22.40	22.85	21.75	20.47	20.19	19.21
Elfisher	13.62 N	25.33 E	21.56	21.44	24.54	25.29	24.31	24.15	22.67	21.19	22.58	23.85	—	—
Shambuk	15.67 N	32.55 E	23.90	23.38	—	27.45	23.21	26.15	23.55	25.46	24.05	23.51	23.82	22.53
Sweden														
Karlsbad	59.37 N	13.47 E	1.76	3.13	5.02	14.01	19.90	16.70	20.92	14.14	10.52	3.98	1.47	0.94

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Lat.	Long.	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.
Sweden														
Lund	55.72 N	13.22 E	1.97	3.47	6.66	12.48	17.83	13.38	18.74	14.99	10.39	5.45	—	1.21
Stockholm	59.35 N	18.07 E	1.32	2.66	4.75	13.21	15.58	14.79	20.52	14.48	10.50	4.04	1.19	0.83
Switzerland														
Grevea	46.25 N	6.11 E	2.56	7.21	9.46	17.07	20.98	19.78	22.38	20.50	13.62	8.44	3.31	2.87
Zurich	47.48 N	8.53 E	2.31	7.02	7.54	15.04	16.33	16.73	20.28	18.32	12.52	7.18	2.64	2.29
Thailand														
Bangkok	13.73 N	100.57 E	16.67	19.34	23.60	22.48	20.59	17.71	18.02	16.04	16.25	16.81	18.60	16.43
Trinidad & Tobago														
Crown Point	10.15 N	60.83 W	13.05	15.61	15.17	16.96	17.61	15.37	13.16	13.08	12.24	9.76	—	—
Tunisia														
Sidi Bouzid	36.87 N	10.35 E	7.88	10.48	13.20	17.98	23.12	26.68	27.43	24.33	18.87	12.11	9.37	6.72
Tunis	36.83 N	10.23 E	7.64	9.88	14.79	31.61	25.31	26.03	26.60	20.37	19.58	12.91	9.35	7.16
Ukraine														
Kiev	50.40 N	30.45 E	2.17	4.67	11.15	12.40	20.49	—	18.99	18.55	9.72	9.84	3.72	2.52
Uzbekistan														
Tashkent	41.27 N	69.27 E	7.27	10.81	15.93	23.60	23.21	29.33	28.50	26.68	20.76	13.25	—	—
Venezuela														
Caracas	10.30 N	66.88 W	14.25	13.96	16.30	15.56	15.69	15.26	16.28	17.11	17.04	15.14	14.74	13.50
St. Antonio	7.85 N	72.45 W	11.78	10.54	10.65	12.07	12.65	21.20	14.66	15.66	16.62	15.32	12.28	11.28
St. Fernando	7.90 N	67.42 W	14.92	16.82	16.89	—	—	14.09	13.78	14.42	14.86	15.27	14.25	11.11
Vietnam														
Hanoi	21.03 N	105.85 E	5.99	7.48	8.73	13.58	19.10	21.26	19.85	19.78	20.67	14.78	12.44	13.21

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Lat	Long	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.
Vologdavia	44.78 N	26.33 E	4.92	6.27	10.64	14.74	20.95	22.80	22.09	20.27	15.57	11.24	6.77	4.99
Bergraud	43.38 N	20.90 E	1.03	10.93	14.75	12.28	13.54	20.43	22.48	—	20.14	11.61	6.26	4.64
Kopanuit	45.32 N	13.57 E	5.11	7.84	13.75	17.30	23.66	22.31	25.14	21.34	13.40	4.98	6.04	3.92
Portofoz	45.32 N	13.57 E												
Lambia														
Lusaka	15.42 S	28.32 W	16.10	18.02	20.24	19.84	17.11	16.37	19.45	20.72	21.68	23.83	23.85	20.52
Zimbabve														
Rudawayo	20.15 S	26.62 N	20.03	22.11	21.03	18.09	17.15	15.36	16.46	19.49	21.55	23.44	23.46	
Hatze	17.43 S	31.02 N	19.38	19.10	19.22	17.67	18.35	16.10	14.55	17.87	21.47	23.98	19.92	21.88

(Source: Voevodov Main Geophysical Observatory, Russia. Internet address: <http://www.mgo.trety.ru/gc/gc-data-3p.html>)

Note: Data for 672 locations is available from these sources in 68 countries.

*Source for Canadian Data: Environment Canada. Internet address: <http://www.ec.gc.ca/emp/home.html>

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	Average
Alabama													
Birmingham	9.20	11.92	15.67	19.65	21.58	22.37	21.24	20.21	17.15	14.42	10.22	8.40	16.01
Montgomery	9.54	12.49	16.24	20.33	22.37	23.17	21.80	20.56	17.72	14.99	10.90	8.97	16.58
Alaska													
Fairbanks	0.62	2.77	8.31	14.66	17.98	19.65	16.92	12.36	7.02	3.20	1.01	0.23	8.34
Anchorage	1.02	3.41	8.18	13.06	15.90	17.72	16.69	12.72	8.08	3.97	1.48	0.56	8.63
Nome	0.51	2.95	8.29	13.22	18.97	19.65	16.59	11.81	7.72	3.63	0.99	0.09	8.86
St. Paul Island	1.82	4.32	8.52	12.72	14.68	14.42	12.83	10.33	7.84	4.54	2.16	1.25	7.95
Yellowtail	1.36	3.63	7.72	12.61	14.76	15.79	14.99	12.15	7.93	3.97	1.82	0.86	8.18
Arizona													
Phoenix	11.58	15.33	19.87	25.44	28.85	30.69	27.37	25.44	21.92	17.60	12.95	10.56	20.56
Tucson	12.38	15.90	20.21	25.44	28.39	29.30	25.44	24.08	21.58	17.94	13.63	11.24	20.44
Arkansas													
Little Rock	9.09	11.81	15.56	19.19	21.80	23.51	21.37	21.35	17.26	14.08	9.77	8.06	16.24
Ft. Smith	9.31	12.15	15.67	19.31	21.69	23.39	23.63	24.46	17.26	13.97	9.88	8.29	16.45
California													
Bakersfield	8.29	11.92	16.09	22.15	26.57	28.96	28.73	26.01	21.35	15.90	10.33	7.61	18.74
Fresno	7.61	11.58	16.81	22.49	27.14	29.07	28.96	25.89	21.12	15.56	9.65	6.70	18.62
Long Beach	9.99	12.93	17.03	21.60	23.17	24.19	26.12	24.08	19.31	14.99	11.24	9.31	17.83
Sacramento	6.93	10.68	15.56	21.24	25.89	28.62	25.12	20.56	14.54	8.63	6.25	4.72	
San Diego	11.02	13.87	17.72	21.92	22.49	23.28	24.98	23.51	19.53	12.79	10.22	8.06	18.06
San Francisco	7.72	10.68	15.22	20.44	24.08	25.78	26.46	23.39	19.31	13.97	9.87	7.04	16.92
Los Angeles	10.11	13.06	17.26	21.80	23.05	23.74	25.67	23.51	18.97	14.99	11.36	9.31	17.22
Santa Maria	10.22	13.29	17.49	22.26	25.10	26.57	26.91	24.42	20.10	15.63	11.47	9.34	18.62
Colorado													
Boulder	7.84	10.45	15.64	17.94	17.94	20.47	20.28	17.12	16.07	12.09	8.66	7.10	14.31
Colorado Springs	9.09	12.15	16.13	20.33	22.26	24.98	23.96	21.69	18.51	14.42	9.99	8.18	15.81
Connecticut													
Hartford	6.70	9.65	13.17	16.69	19.53	21.24	21.12	18.51	14.76	10.68	6.59	5.45	13.74

**Worldwide, Horizontal Surface
Solar Radiation Data, [MJ/m²-day]**

Position	Jan	Feb	Mar	Apr.	May	June	July	Aug	Sep	Oct	Nov	Dec.	Average
Delaware													
Wilmington	7.27	10.21	13.97	17.60	20.33	22.49	21.80	19.65	15.79	11.81	7.94	6.25	14.65
Florida													
Daytona Beach	11.24	13.85	17.94	22.15	23.17	22.63	21.69	20.44	17.72	14.99	12.15	10.33	17.38
Jacksonville	10.43	13.17	17.01	21.12	22.03	21.58	21.01	20.90	19.65	17.72	15.56	11.92	16.47
Tallahassee	10.19	13.29	16.92	21.24	22.49	22.03	21.10	20.10	19.42	16.69	14.20	9.77	16.81
Miami	12.72	15.22	18.51	21.53	21.46	21.46	21.00	20.10	19.65	17.72	15.56	11.92	17.38
Key West	13.17	16.01	19.65	22.71	22.83	22.03	21.01	20.10	19.42	17.60	15.67	13.17	18.40
Tampa	11.58	14.42	18.17	22.26	23.05	21.92	20.90	19.65	17.60	15.47	13.85	11.71	17.49
Georgetown													
Athens	9.43	12.38	16.01	20.21	22.03	22.83	21.60	20.21	17.26	14.42	10.45	8.40	16.29
Atlanta	9.31	12.26	16.13	20.12	22.37	23.17	22.15	20.56	17.39	14.54	10.76	8.52	16.43
Columbus	9.77	12.72	16.47	20.67	22.37	22.83	21.58	20.33	17.60	14.99	11.02	9.99	16.62
Memphis	9.54	12.61	16.35	20.56	22.37	22.83	21.58	20.21	17.26	14.83	10.90	8.86	16.30
St. Louis	9.99	12.72	16.81	21.01	22.37	22.60	21.80	19.76	16.92	14.65	11.13	9.20	16.36
Hawaii													
Honolulu	14.08	16.92	19.42	21.24	22.83	23.51	23.74	23.28	21.35	18.06	14.88	11.40	19.42
Idaho													
Rose	5.79	8.97	13.63	18.97	23.51	26.01	27.37	23.62	18.40	12.26	6.70	5.11	15.90
Blaine													
Chicago	6.47	9.31	12.49	16.37	20.44	22.60	22.03	19.31	15.10	10.79	6.47	5.22	13.85
Rockford	6.70	9.77	12.72	16.56	20.33	22.49	22.15	19.42	15.22	10.79	6.59	5.34	14.08
Springfield	7.50	10.33	13.40	17.83	21.46	23.51	23.05	20.56	16.53	12.25	7.72	6.13	15.10
Indiana													
Indianapolis	7.03	9.99	13.17	17.49	21.24	23.28	22.60	20.33	16.35	11.92	7.38	5.79	14.76
Iowa													
Mason City	6.70	9.77	13.29	16.92	20.78	22.83	22.71	19.76	15.33	10.90	6.39	5.43	14.31
Waterloo	6.81	9.77	13.06	16.92	20.56	22.83	22.60	19.76	15.33	10.90	6.70	5.45	14.20

**Worldwide, Horizontal Surface
Solar Radiation Data, [MJ/m²-day]**

Position	Jan	Feb	Mar	Apr.	May	June	July	Aug	Sep	Oct	Nov	Dec.	Average
Kansas													
Dodge City	9.65	12.83	16.69	21.01	21.28	25.78	25.67	23.60	18.40	14.42	10.11	8.40	17.49
Goodland	6.97	11.92	16.13	20.44	22.71	25.78	25.55	22.69	18.28	14.08	9.65	7.84	17.03
Kentucky													
Lexington	7.27	9.88	13.51	17.60	20.56	22.26	21.46	19.65	16.01	12.38	7.95	6.25	14.54
Louisville	7.27	10.22	13.63	17.83	20.90	22.71	22.03	20.10	16.35	12.38	7.95	6.25	14.76
Louisiana													
New Orleans	9.77	12.83	16.01	19.87	21.80	22.03	20.67	19.65	17.50	13.56	11.24	9.31	16.35
Lake Charles	9.77	12.83	16.13	19.31	21.58	22.71	21.58	20.33	18.06	15.56	11.47	9.31	16.58
Maine													
Portland	6.70	9.99	13.78	16.92	19.99	21.92	21.69	19.31	15.22	10.56	6.47	5.45	13.97
Maryland													
Baltimore	7.38	10.33	13.97	17.60	20.21	22.15	21.69	19.19	15.79	11.92	8.06	6.36	14.54
Massachusetts													
Boston	6.20	9.65	13.40	16.92	20.21	22.03	21.80	19.31	15.33	10.79	6.81	5.45	14.08
Michigan													
Detroit	5.91	8.86	12.38	16.47	20.33	22.37	21.92	18.97	14.76	10.11	6.13	4.66	13.63
Lansing	5.91	8.86	12.49	16.56	20.21	22.26	21.92	18.85	14.54	9.77	5.91	4.66	13.51
Minnesota													
Duluth	5.68	9.31	13.74	17.36	20.10	21.46	21.80	18.28	13.29	8.86	5.34	4.41	13.29
Minneapolis	6.36	9.77	13.51	16.92	20.56	22.49	22.83	19.42	14.65	9.99	6.13	4.88	13.97
Rochester	6.26	9.63	13.17	16.56	20.10	22.15	22.15	19.08	14.53	10.11	6.25	5.11	13.74
Mississippi													
Jackson	9.43	12.38	16.13	19.87	22.15	23.05	22.15	19.08	14.54	10.11	6.25	5.11	13.74
Missouri													
Columbia	8.06	10.90	14.31	18.62	21.38	23.62	23.85	21.12	16.69	12.72	8.29	6.70	15.56
Kansas City	7.95	10.68	14.68	18.28	21.24	23.28	23.62	20.78	16.58	12.72	8.40	6.70	15.44
Springfield	8.52	11.02	14.65	18.62	21.24	23.03	23.62	21.24	16.81	13.17	8.36	7.27	15.67
St. Louis	7.84	10.56	13.97	18.06	21.12	23.05	23.94	20.44	16.58	12.49	8.18	6.59	15.22

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.	Average
Montana Helena	5.22	8.29	12.61	17.15	20.67	23.28	25.21	21.24	15.79	10.45	6.02	4.43	14.20
Leavenworth Nebraska	5.22	8.40	12.72	17.15	20.33	23.05	24.53	20.78	15.10	10.22	5.91	4.32	13.97
Lincoln Nevada	7.50	10.33	13.97	18.06	21.24	2.40	23.51	20.46	16.01	11.81	7.61	6.13	15.10
Eliot Las Vegas	7.61	10.56	14.42	18.85	22.71	25.67	26.69	23.62	19.31	13.63	8.29	6.70	16.58
Reno New Hampshire	8.79	11.58	16.24	21.24	25.10	27.48	28.16	24.98	20.56	14.88	9.31	7.38	17.94
Concord New Jersey	6.81	10.11	13.97	16.92	20.21	21.80	21.80	19.98	14.99	10.45	6.47	5.45	14.08
Atlantic City Newark	7.38	10.22	13.97	17.49	20.21	21.92	21.24	19.19	15.79	11.32	8.06	6.36	14.54
New Mexico Albuquerque	6.93	9.77	13.51	17.26	19.76	21.35	21.01	18.85	15.33	11.36	7.27	5.68	13.97
New York Albany	6.36	9.43	12.95	16.69	19.53	21.46	21.58	18.51	14.65	10.11	6.13	5.00	13.51
Buffalo	5.68	8.40	12.15	16.35	19.76	22.03	21.69	18.62	14.08	9.54	5.68	4.54	13.29
New York City Rockford	6.93	9.88	13.85	17.72	20.44	22.03	21.69	19.42	15.56	11.47	7.27	5.79	14.21
North Carolina Charlotte	5.68	8.52	12.26	16.58	19.87	21.92	21.69	18.51	14.20	9.54	5.68	4.54	13.29
Wilmington North Dakota	9.31	12.15	16.24	20.44	21.92	22.60	21.92	19.99	16.92	13.97	9.99	8.06	16.01
Fargo Bismarck	5.79	9.09	13.17	16.92	20.56	22.37	23.17	19.87	14.31	9.54	5.68	4.54	13.74
	6.12	9.75	13.88	17.43	21.45	23.01	24.06	20.12	15.21	10.61	6.26	4.84	14.39

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Position	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.	Average
Ohio Cleveland	5.70	8.63	12.04	16.58	20.10	22.15	21.92	18.97	14.76	10.22	6.02	4.66	13.51
Columbus Dixie	6.47	9.69	12.49	16.58	19.76	21.58	21.12	18.97	15.44	11.34	6.81	5.34	13.74
Towntown Oklahoma	5.70	8.40	11.92	15.90	18.97	20.33	22.37	19.65	14.47	10.47	6.02	4.45	13.20
Oklahoma City Oregon	9.38	12.25	16.47	20.33	22.26	24.42	24.98	22.49	18.17	14.54	10.45	8.74	17.15
Eugene Portland	4.54	7.04	11.24	15.79	19.99	22.37	24.19	21.01	15.90	11.34	7.72	6.02	14.31
Pacific Islands Guam	5.34	8.52	12.17	16.62	20.39	22.39	22.82	19.62	15.20	10.90	6.59	5.03	13.63
Pennsylvania Philadelphia	7.04	9.88	13.63	17.26	19.96	22.03	21.46	19.42	15.67	11.58	7.72	6.02	14.31
Pittsburgh Rhode Island	6.25	8.97	12.51	16.47	19.65	21.80	21.35	18.85	15.10	10.90	6.59	5.03	13.63
Providence South Carolina	6.70	9.05	13.40	16.92	19.99	21.58	21.24	18.85	15.22	11.02	6.93	5.56	13.97
Charleston Greenville	9.77	12.72	16.41	21.12	22.37	22.37	21.92	19.65	16.92	14.54	11.02	9.09	16.58
South Dakota Pierre	9.20	12.04	15.90	19.99	21.58	22.60	21.58	19.87	16.81	14.08	10.22	8.16	16.01
Rapid City Tennessee	6.47	9.54	13.85	17.94	21.46	24.08	24.42	21.46	16.35	11.24	7.04	5.45	14.99
Memphis Nashville	8.86	11.58	15.72	19.42	22.01	23.85	23.39	21.46	17.34	14.20	9.65	7.84	16.24
	8.29	11.13	14.65	19.31	21.69	23.51	22.49	20.56	16.81	13.51	8.97	7.15	15.67

Worldwide, Horizontal Surface Solar Radiation Data, [MJ/m²-day]

Location	Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	Average
Texas	10.68	13.61	17.03	19.53	21.24	23.74	24.42	22.83	18.85	15.67	11.92	9.99	17.49
Abilene	10.33	13.17	16.47	19.08	20.78	22.83	23.28	21.58	18.62	16.13	12.38	9.98	17.03
Brownsville	12.38	16.24	20.90	25.44	28.05	28.15	26.46	24.30	21.13	17.72	13.63	11.47	20.58
El Paso	9.54	12.26	15.22	18.06	20.21	21.69	21.35	20.21	17.49	15.10	11.02	8.97	15.90
Houston	10.88	13.53	16.26	17.35	21.10	23.87	24.92	22.81	19.22	15.52	11.50	9.98	17.24
San Antonio	6.93	10.45	14.26	19.42	23.39	26.46	26.35	23.39	18.85	13.29	8.06	6.02	16.47
Utah													
Salt Lake City													
Vermont													
Burlington	5.79	9.20	13.06	16.47	19.87	21.69	21.80	18.74	14.42	9.43	5.36	4.43	13.40
Virginia													
Norfolk	8.06	10.90	14.65	18.51	20.78	22.15	21.12	19.42	16.13	12.49	9.09	7.27	15.10
Richmond	8.06	10.90	14.76	18.62	20.90	23.49	21.56	19.53	16.24	12.64	8.97	7.15	15.22
Washington													
Olympia	3.63	6.02	9.99	14.20	18.06	20.10	21.12	18.37	13.69	7.95	4.32	3.07	11.70
Seattle	3.52	5.91	10.11	14.65	19.08	20.78	21.30	18.31	13.51	7.95	4.20	2.84	11.92
Albion	4.88	7.05	12.83	17.83	22.49	24.87	25.39	22.26	16.92	10.65	5.36	4.09	17.76
West Virginia													
Charleston	7.04	9.63	13.40	17.15	20.21	21.69	20.90	18.97	15.56	11.81	7.72	6.02	14.20
Elkins	6.93	9.43	12.83	16.35	19.08	20.56	19.99	18.06	14.86	11.11	7.17	5.79	13.51
Wisconsin													
Green Bay	6.25	9.31	13.17	16.81	20.56	22.49	22.03	18.85	14.20	9.65	5.79	4.88	13.74
Madison	6.59	9.88	13.79	16.92	20.67	22.83	22.17	19.42	14.76	10.34	6.25	5.22	14.08
Milwaukee	6.47	9.31	12.72	16.69	20.78	22.94	22.60	19.42	14.88	10.22	6.25	5.11	13.97
Wyoming													
Rock Springs	7.61	10.90	15.10	19.42	23.17	26.01	25.78	22.94	18.62	13.40	8.40	6.70	16.58
Seaman	6.47	9.77	13.97	17.14	20.90	23.85	24.64	21.69	16.47	11.24	7.15	5.56	14.99

(Source: National Renewable Energy Laboratory, USA, Internet Address <http://Nrel.nrel.gov/pv/>)

Solar Radiation on Tilted Surfaces

The worldwide horizontal surface data on pages 18-31 can be used to estimate solar radiation on tilted surfaces. This section outlines a procedure to use this data to estimate the solar radiation on equatorial-facing, tilted collectors. Nomographs are provided for common tilt angles of: tilt equal to the site latitude and the latitude +/- 15°.

Procedure:

1. Obtain the monthly averaged, daily total radiation, \bar{H}_h , for the chosen location and month of interest, pages 18-31
 2. Compute the monthly clearness index, \bar{K}_t :
- $$\bar{K}_t = \frac{\bar{H}_h}{\bar{H}_{oh}} \quad \text{Where } \bar{H}_{oh} \text{ is the extraterrestrial horizontal}$$
- surface radiation and can be read from Fig. c-1 on page 33.
3. Determine the sunset hour angle, h_{ss} , from Fig. c-2 page 34, (positive value).
 4. Compute the diffuse to total radiation ratio, $\frac{D}{H_h}$:
- $$\frac{D}{H_h} = 0.775 + 0.347\left(h_{ss} - \frac{\pi}{2}\right) - \left[0.505 + 0.0261\left(h_{ss} - \frac{\pi}{2}\right)\right]\cos(2\bar{K}_t - 1.8)$$
- Note: h_{ss} in radians
5. Solve for the diffuse and beam radiation components:
- $$\bar{D}_h = \left(\frac{D}{H_h}\right)\bar{H}_h \quad \text{and} \quad \bar{B}_h = \bar{H}_h - \bar{D}_h$$

6. Determine the collector tilt factor, \bar{R}_b , for the tilt angle, β , of interest. Use the following formulation or Figs. c-3-5 for common tilt orientations.

$$\bar{R}_b = \frac{\cos(L - \beta) \cos(\delta_s) \sin(h_{sr}) + h_{sr} \sin(L - \beta) \sin(\delta_s)}{\cos(L) \cos(\delta_s) \sin(h_{sr}) + h_{sr} \sin(L) \sin(\delta_s)}$$

Where δ_s is the declination angle, page 4, and h_{sr} is the hour angle at sunrise, Fig. c-2 (negative value, radians)

7. Compute the collector monthly-averaged radiation total, \bar{H}_c .

$$\bar{H}_c = \bar{R}_b \bar{B}_h + \bar{D}_h \cos^2\left(\frac{\beta}{2}\right) + (\bar{D}_h + \bar{B}_h) \rho \sin^2\left(\frac{\beta}{2}\right)$$

Assuming an appropriate reflectivity value, ρ , from the table on page 36.




Figure c-1. \bar{H}_{oh} , extraterrestrial, monthly averaged, daily insolation on a horizontal surface.

33




Figure c-2. Sunrise and Sunset hour angles




Figure c-3. \bar{R}_b for tilt = L.

34




Figure c-4. \bar{R}_b for tilt = $L = 15$




Figure c-5. \bar{R}_b for tilt = $L + 15$.

Reflectivity values for characteristic surfaces (integrated over solar spectrum and angle of incidence)^a.

Surface	Average reflectivity
Snow (freshly fallen or with ice film)	0.75
Water surfaces (relatively large incidence angles)	0.07
Soils (clay, loam, etc.)	0.14
Earth roads	0.04
Coniferous forest (winter)	0.07
Forests in autumn, ripe field crops, plants	0.26
Weathered blacktop	0.10
Weathered concrete	0.22
Dead leaves	0.30
Dry grass	0.20
Green grass	0.26
Bituminous and gravel roof	0.13
Crushed rock surface	0.20
Building surfaces, dark (red brick, dark paints, etc.)	0.27
Building surfaces, light (light brick, light paints, etc.)	0.60

^aFrom Hunn, B. D., and D. O. Calafell, Determination of Average Ground Reflectivity for Solar Collectors, *Sol. Energy*, vol. 19, p. 87, 1977; see also R. J. List, "Smithsonian Meteorological Tables," 6th ed., Smithsonian Institution Press, pp. 442-443, 1949.

Estimation of UV Insolation

Nomenclature

I_t global horizontal total solar radiation

$I_{t,b}$ beam component of total solar radiation

$I_{uv,h}$ beam component of UV radiation

$I_{uv,b}$ global horizontal UV radiation

K_t cloudiness index

m air mass

α solar altitude angle

$$\frac{I_{uv,h}}{I_t} = 0.14315K_t^2 - 0.20445K_t + 0.135544$$

$$\frac{I_{uv,b}}{I_{t,b}} = 0.0688e^{-0.575m} = 0.688 \exp\left(\frac{-0.575}{\sin \alpha}\right)$$

Radiation Heat Transfer Properties

Surface emissivity, ε , which is the emission of the surface compared to an ideal blackbody, E/E_b

$$\varepsilon = \frac{E}{E_b} = \frac{1}{\sigma T^4} \int_0^\infty \varepsilon_\lambda E_{\text{b}\lambda} d\lambda$$

Where σ is the Stefan-Boltzmann constant, $(5.670 \times 10^{-8} \text{ W/m}^2 \text{ K}^4)$, T is surface temperature and the subscript λ refers to wavelength.

Incident radiation balance: $\alpha + \tau + \rho = 1$

Where:

$$\text{absorptivity } \alpha \equiv \frac{\text{absorbed}}{\text{I}} \quad \text{transmissivity } \tau \equiv \frac{\text{trans}}{\text{I}}$$

$$\text{reflectivity: } \rho \equiv \frac{\text{refl}}{\text{I}} \quad \text{and I is the total surface irradiation.}$$

Emissivity and absorptivity of common materials

Substance	Short-wave absorptance	Long-wave emittance	α/ε
Class I substances: Absorptance to emittance ratios less than 0.5			
Magnesium carbonate, MgCO_3	0.025-0.04	0.79	0.01-0.05
White plaster	0.07	0.91	0.08
Snow, fine particles, fresh	0.13	0.82	0.16
White paint, 0.017 in. on aluminum	0.20	0.91	0.22
White wash on galvanized iron	0.22	0.90	0.24
White paper	0.25-0.28	0.95	0.26-0.29
White enamel on iron	0.25-0.45	0.9	0.28-0.5
Ice, with sparse snow cover	0.31	0.96-0.97	0.32
Snow, ice granules	0.33	0.89	0.37
Aluminum oil base paint	0.45	0.90	0.50
White powdered sand	0.45	0.84	0.54

Emissivity and absorptivity of common materials, continued from page 37.

Substance	Short-wave absorptance	Long-wave emittance	α/ε
Class II substances: Absorptance to emittance ratios between 0.5 and 0.9			
Asbestos felt	0.25	0.50	0.50
Green oil base paint	0.5	0.9	0.56
Bricks, red	0.55	0.92	0.60
Asbestos cement board, white	0.59	0.96	0.61
Marble, polished	0.5-0.6	0.9	0.61
Wood, planed oak	—	0.9	—
Rough concrete	0.60	0.97	0.62
Concrete	0.60	0.88	0.68
Grass, green, after rain	0.67	0.98	0.68
Grass, high and dry	0.67-0.69	0.9	0.76
Vegetable fields and shrubs, wilted	0.70	0.9	0.78
Oak leaves	0.71-0.78	0.91-0.95	0.78-0.82
Frozen soil	—	0.93-0.94	—
Desert surface	0.75	0.9	0.83
Common vegetable fields and shrubs	0.72-0.76	0.9	0.82
Ground, dry plowed	0.75-0.80	0.9	0.83-0.89
Oak woodland	0.82	0.9	0.91
Pine forest	0.86	0.9	0.96
Earth surface as a whole (land and sea, no clouds)	0.83	—	—

Class III substances: Absorptance to emittance ratios between 0.8 and 1.0

Substance	Short-wave absorptance	Long-wave emittance	α/ε
Class I substances: Absorptance to emittance ratios less than 0.5			
Grey paint	0.75	0.95	0.79
Red oil base paint	0.74	0.90	0.82
Asbestos, slate	0.81	0.96	0.84
Asbestos, paper	—	0.93-0.96	—
Limeburn, red-brown	0.84	0.92	0.91
Dry sand	0.82	0.90	0.91
Green oil roofing	0.88	0.91-0.97	0.91
Slate, dark grey	0.89	—	—
Old grey rubber	—	0.86	—
Hard black rubber	—	0.90-0.95	—
Asphalt pavement	0.93	—	—
Black cupric oxide on copper	0.91	0.96	0.95
Bare moist ground	0.9	0.95	0.95
Wet sand	0.91	0.95	0.96
Water	0.94	0.95-0.96	0.98
Black tar paper	0.91	0.93	1.0
Black glass paint	0.90	0.91	1.0
Small hole in large box, furnace, or enclosure	0.99	0.99	1.0
"Hohraum," theoretically perfect black body	1.0	1.0	1.0

**Emissivity and absorptivity of common materials,
continued from page 37**

Substance	Short-wave absorptance	Long-wave emittance	σ ϵ
Class IV substances: Absorptance to emittance ratios greater than 1.0			
Black silk velvet	0.99	0.97	1.02
Altafin, dark green	0.97	0.95	1.02
Lampblack	0.98	0.95	1.01
Black paint, 0.017 in. on aluminum	0.94-0.98	0.88	1.07-1.11
Granite	0.55	0.44	1.25
Graphite	0.78	0.41	1.90
High ratios, but absorptances less than 0.80			
Dull brass, copper, lead	0.2-0.4	0.4-0.65	1.63-2.0
Galvanized sheet iron, oxidized	0.8	0.28	2.86
Galvanized iron, clean, new	0.65	0.13	5.0
Aluminum foil	0.15	0.09	1.00
Magnesium	0.3	0.07	4.3
Chromium	0.49	0.08	6.13
Polished zinc	0.46	0.02	21.0
Deposited silver (optical reflector) unpolished	0.07	0.01	
Class V substances: Selective surfaces*			
Plated metals**			
Black sulfide on metal	0.92	0.10	9.2
Black cupric oxide on sheet aluminum	0.08-0.93	0.09-0.21	
Copper (5×10^{-3} cm thick) on nickel or silver plated metal			
Cobalt oxide on platinum			
Cobalt oxide on polished nickel	0.93-0.94	0.24-0.40	1.9
Black nickel oxide on aluminum	0.85-0.93	0.06-0.1	14.5-15.5
Black chrome	0.87	0.09	9.8
Particulate coatings:			
Lampblack on metal			
Black iron oxide, 47 μ m grain size, on aluminum			
Geometrically enhanced surfaces***			
Optimally corrugated greys	0.89	0.77	1.2
Optimally corrugated selectives	0.95	0.16	5.9
Stainless-steel wire mesh	0.63-0.86	0.23-0.28	2.7-3.0
Copper, treated with NaClO_2 and NaOH	0.87	0.13	6.69

*From Anderson, B., "Solar Energy," McGraw-Hill Book Company, 1972, with permission.

**Selective surfaces absorb most of the solar radiation between 0.3 and 1.9 μm , and emit very little in the 5-15 μm range—the infrared.

***For a discussion of plated selective surfaces, see Daniels, "Direct Use of the Sun's Energy," especially chapter 12.

****For a discussion of how surface selectivity can be enhanced through surface geometry, see K. G. T. Hollands, "Directional Selectivity, Emittance and Absorptance Properties of Vee Corrugated Specular Surfaces," *J. Sol. Energy Sci. Eng.*, vol. 3, July 1963.

Properties of some selective plated coating systems*

Coating**	Substrate	$\bar{\alpha}_s$	$\bar{\epsilon}_s$	Durability	Humidity-Degradation MIL-STD 810B
Black nickel on nickel	Steel	0.95	0.07	>290	Variable
Black chrome on nickel	Steel	0.95	0.09	>430	No effect
Black chrome	Steel	0.91	0.07	>430	Complete rusted
	Copper	0.95	0.14	315	Little effect
	Galvanized steel	0.95	0.16	>30	Complete removal
	Copper	0.88	0.15	315	Little effect
	Steel	0.85	0.08	430	Little effect
	Aluminum	0.70	0.08		
	Steel	0.90	0.16		
	Steel	0.94	0.20		
Black copper				Line effect	
Iron oxide				Line effect	
Manganese oxide				Line effect	
Organic overcoat on iron oxide				Line effect	
Organic overcoat on black chrome				Line effect	

*From U.S. Dept. of Commerce, "Optical Coatings for Flat Plate Solar Collectors," NTIS No. PB-252-283, Honeywell, Inc., 1975.
**Black nickel coating plated over a nickel-plated substrate has the best selective properties ($\bar{\alpha}_s = 0.95$, $\bar{\epsilon}_s = 0.07$), but these degraded significantly during humidity tests. Black chrome plated on a nickel-plated substrate also had very good selective properties ($\bar{\alpha}_s = 0.95$, $\bar{\epsilon}_s = 0.09$) and also showed high resistance to humidity.

Angular variation of the absorptivity of lampblack paint

Incidence angle (i°)	Absorptance $a(i)$
0-10	0.96
30-40	0.95
40-50	0.93
50-60	0.91
60-70	0.88
70-80	0.81
80-90	0.66

Adapted from [9]

Reflectivity values for reflector materials

Material	ρ
Silver (useable as front surface mirror)	0.94 ± 0.02
Gold	0.76 ± 0.03
Aluminized acrylic, second surface	0.96
Anodized aluminum	0.82 ± 0.05
Various aluminum surfaces-range	0.82-0.92
Copper	0.75
Buck-silvered water-white plate glass	0.88
Aluminized type-C Mylar (from Mylar side)	0.76


Spectral Absorption of Solar Radiation in Water

Wavelength (nm)	Layer depth				
	0	1 cm	10 cm	1 m	10 m
0.2-0.6	23.7	23.7	23.6	22.9	17.2
0.6-0.9	36.0	35.3	36.0	12.9	0.9
0.9-1.2	17.9	12.3	0.8	0.0	0.0
1.2 and over	22.4	1.7	0.0	0.0	0.0
Total	100.0	73.0	54.9	35.8	18.1

*Numbers in the table give the percentage of sunlight in the wavelength band passing through water of the indicated thickness.

Transparent Materials

Refraction of light between materials



Index of refraction:

$$\frac{\sin(i)}{\sin(\theta_r)} = \frac{n'}{n_i} = n$$

Visible spectrum refractive index values, n_r , based on air

Material	Index of Refraction
Air	1.00
Clean polycarbonate	1.59
Diamond	2.42
Glass (solar collector type)	1.50-1.52
Plexiglas® (polymethyl methacrylate, PMMA)	1.49
Mylar® (polyethylene terephthalate, PET)	1.64
Quartz	1.54
Teflon® (polytetrafluoroethylene, FEP)	1.34
Water-liquid	1.33
Water-solid	1.31

®Trademark of the duPont Company, Wilmington, Delaware.

Thermal and radiative properties of collector cover materials*

Material name	Index of refraction (n)	τ_{solary} (%)	τ_{solar}^* (%)	τ_{infrared}^* (%)	Expansion coefficient ($\text{m/m} \times ^\circ\text{C}$)	Temperature limits ($^\circ\text{C}$)	Weatherability (comment)	Chemical resistance (comment)
Lexan (polycarbonate)	1.586 (D 542)	125 mil 64.1 (± 0.8)	125 mil 72.6 (± 0.1)	125 mil 2.0 (test)	6.75 (10^{-3}) (H 696)	121-132 service temperature	Good 2 yr exposure in Florida caused yellowing, 5 yr caused 5% loss in τ	Good; comparable to acrylic
Plexiglas (acrylic)	1.49 (D 542)	125 mil 85.6 (± 0.3)	125 mil 79.6 (± 0.8)	125 mil 2.0 (test)	7.02 (10^{-4}) at (10^{-5}) at 38°C	82-93 service temperature	Average to good based on 20 yr testing in Arizona, Florida and Pennsylvania	Good to excellent results most acids and alkalis
Teflon FEP (fluorocarbon)	1.341 (D 542)	5 mil 92.3 (± 0.2)	5 mil 89.8 (± 0.8)	5 mil 2.5 (test)	1.06 (10^{-3}) at (10^{-4}) at 100°C	204 continuous use, 246 short-term use	Good to excellent based on 15 yr exposure in Florida environment	Excellent chemically inert
Tedlar PVF (fluorocarbon)	1.46 (D 542)	4 mil 92.2 (± 0.1)	4 mil 88.7 (± 0.4)	4 mil 2.0 (± 0.5)	5.04 (10^{-3}) (10^{-4}) at 100°C	107 continuous use, 177 short-term use	Good to excellent 10 yr exposure in Florida with slight yellowing	Excellent chemically inert
Mylar (polyester)	1.64-1.67 (D 542)	3 mil 86.9 (± 0.3)	5 mil 80.1 (± 0.5)	3 mil 17.8 (± 0.5)	1.69 (10^{-3}) (D 696-44)	150 continuous use, 204 short term use	Poor ultraviolet degradation great	Good to excellent comparable to Tedlar
Sundlite (fiberglass)	1.54 (D 542)	25 mil (P) 85.5 (± 0.2)	25 mil (P) 75.4 (± 0.1)	25 mil (P) 7.6 (± 0.1)	2.5 (10^{-1}) (D 696)	93 continuous use causes 5% loss in τ	Fair to good regular 3 yr solar life, premium 20 yr solar life	Good inert to chemical atmosphere
Floerglass (glass)	1.518 (D 542)	125 mil 84.3 (± 0.1)	125 mil 78.6 (± 0.2)	125 mil 2.0 (test)	8.64 (10^{-4}) (D 696)	732 softening point, 38 thermal shock	Excellent time proved	Good to excellent, time proved

Thermal and radiative properties of collector cover materials*

Material name	Index of refraction (n)	τ_{solary} (%)	τ_{solar}^* (%)	τ_{infrared}^* (%)	Expansion coefficient ($\text{m/m} \times ^\circ\text{C}$)	Temperature limits ($^\circ\text{C}$)	Weatherability (comment)	Chemical resistance (comment)
Temper glass (glass)	1.518 (D 542)	125 mil 84.3 (± 0.1)	125 mil 78.6 (± 0.3)	125 mil 2.0 (test)	8.64 (10^{-6}) (D 696)	232-260 continuous use, 260-288 short-term use	Excellent time proved	Good to excellent time proved
Clear lime sheet glass (low iron oxide glass)	1.51 (D 542)	Insufficient data provided by ASG	125 mil 87.5 (± 0.5)	125 mil 2.0 (test)	9 (10^{-6}) (D 696)	204 for continuous operation	Excellent time proved	Good to excellent time proved
Clear lime temper glass (low iron oxide glass)	1.51 (D 542)	Insufficient data provided by ASG	125 mil 87.5 (± 0.5)	125 mil 2.0 (test)	9 (10^{-6}) (D 696)	204 for continuous operation	Excellent time proved	Good to excellent time proved
Sumader white crystal glass (0.015% iron oxide glass)	1.50 (D 542)	Insufficient data provided by ASG	125 mil 91.5 (± 0.2)	125 mil 2.0 (test)	8.46 (10^{-6}) (D 696)	204 for continuous operation	Excellent time proved	Good to excellent time proved

*Numerical integration ($\sum \tau_{\text{infr}} F_{\lambda} (\tau - \tau_{\text{infr}})$) for $\lambda = 0.2-4 \mu\text{m}$ **Numerical integration ($\sum \tau_{\text{infr}} F_{\lambda} (\tau - \tau_{\text{infr}})$) for $\lambda = 3-50.0 \mu\text{m}$.

*All parenthesized numbers refer to ASTM test codes.

*Data not provided; estimate of 2% to be used for 125 mil samples.

°Degrees differential to rupture $2 \times 2 \times \frac{1}{4}$ in samples. Glass specimens heated and then quenched in water bath at 70°C .

*Sundlite premium data denoted by (P). Sundlite regular data denoted by (R).

**Compiled data based on ASTM Code E 424 Method B.

*Abstracted from Ratzel, A. C., and R. B. Barreros, Optimal Material Selection for Flat-Plate Solar Energy Collectors Utilizing Commercially Available Materials, presented at ASME-AIChE Natl. Heat Transfer Conf., 1976

Solar Thermal Collector Overview

General Configuration	Description	Concentration Ratio	Indicative Operating Temp. (°C)
	Non-Convecting Solar Pond	1	30-70
	Un glazed Flat Plate Absorber	1	0-40
	Flat Plate Collector (High Efficiency)	1 (1)	0-70 (60-120)
	Fixed Concentrator	3-5	100-150
	Evacuated Tube	1	50-180
	Compound Parabolic (With 1 Axis Tracking)	1.5 (5-15)	70-240 (70-290)
	Parabolic Trough	10-50	150-350
	Fresnel Refractor	10-40	70-270
	Spherical Dish Reflector	100-300	70-730
	Parabolic Dish Reflector	200-500	250-700
	Central Receiver	500-3000	500->1000

Adapted from [12]


Non-Concentrating Collectors

Efficiency of N-C collectors, Hottel-Whillier equation (European Standard on page 48):

$$\eta_c = F_R \tau_s \alpha_s - F_R U_c \frac{(T_{f,in} - T_a)}{I_c}$$

Where F_R is the collector heat removal factor, τ_s is the cover transmissivity, α_s is the cover-absorber absorptivity, and U_c is the overall collector heat loss conductance. $T_{f,in}$ is the collector fluid inlet temperature, T_a is the ambient, and I_c is the incident radiation on the collector.

Representative performance curves




Incidence Angle Modifier

Incidence angle modifier, K_m , is used to estimate collector performance at non-normal angles of incidence with.

$$\eta_c = F_R \left[K_m (\tau_s \alpha_s)_n - U_c \frac{(T_{f,in} - T_a)}{I_c} \right]$$

where K_m is of the form ($b = \text{constant}$):

$$K_m = 1 - b \left(\frac{1}{\cos(i)} - 1 \right)$$



Incident angle modifier for three flat-plate solar collectors.
Reprinted by permission of the American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc., Atlanta, from
ASHRAE Standard 93-77, "Methods of Testing to Determine the
Thermal Performance of Solar Collectors."

European Standard N-C collector efficiency formulation:

$$\eta_c = F_r \tau_s \alpha_s - a_1 \frac{T_{ave} - T_{amb}}{G} - a_2 \frac{(T_{ave} - T_{amb})^2}{G}$$

Where $T_{ave} = 0.5(T_{i,in} + T_{i,out})$, is used instead of collector inlet temperature and G is the hemispherical irradiance (W/m^2).

The incidence angle modifier is applied in a similar manner
 $\tau_s \alpha_s = K_m (\tau_s \alpha_s)_n$

Concentrating Thermal Collectors

Geometric Concentration Ratio, CR.

$$CR = \frac{A_a}{A_r} \quad \text{where } A_a \text{ is the aperture area and } A_r \text{ is the receiver area.}$$

Instantaneous collector efficiency, η_c :

$$\eta_c = \eta_o - U_c \frac{(T_r - T_a)}{I_c (CR)}$$

Where η_o is the optical efficiency, U_c is the overall collector heat loss conductance, T_r is the receiver temperature, T_a is the ambient temperature, and I_c is the incident radiation on the collector

Incidence factors for various orientation and tracking arrangements of concentrating collectors

Orientation of collector	Incidence factor cos i
Fixed, horizontal, plane surface.	$\sin L \sin \delta_i + \cos \delta_i \cos h_i \cos L$
Fixed plane surface tilted so that it is normal to the solar beam at noon on the equinox.	$\cos \delta_i \cos h_i$
Rotation of a plane surface about a horizontal east-west axis with a single daily adjustment permitted so that its surface normal coincides with the solar beam at noon every day of the year	$\sin^2 \delta_i + \cos^2 \delta_i \cos h_i$
Rotation of a plane surface about a horizontal east-west axis with continuous adjustments to obtain maximum energy incidence.	$\sqrt{1 - \cos^2 \delta_i \sin^2 h_i}$
Rotation of a plane surface about a horizontal north-south axis with continuous adjustment to obtain maximum energy incidence.	$\sqrt{(\sin L \sin \delta_i + \cos L \cos \delta_i \cos h_i)^2 + \cos^2 \delta_i \sin^2 h_i}$
Rotation of a plane surface about an axis parallel to the earth's axis with continuous adjustment to obtain maximum energy incidence	$\cos \delta_i$
Rotation about two perpendicular axes with continuous adjustments to allow the surface normal to coincide with the solar beam at all times.	1

*The incidence factor denotes the cosine of the angle between the surface normal and the solar beam

Adaptation of monthly-averaged, horizontal surface data for tracking concentrators.

$$\bar{H}_c = \left[\bar{\tau} - \bar{\tau} \left(\frac{\bar{D}_h}{\bar{H}_h} \right) \right] \bar{H}_h \quad \text{where:}$$

- \bar{D}_h monthly-average diffuse radiation component for a horizontal surface
- \bar{H}_h monthly-average terrestrial radiation for a tracking collector
- \bar{H}_h monthly-average terrestrial radiation for a horizontal surface
- $\bar{\tau}_d$ diffuse radiation factor
- $\bar{\tau}_t$ tracking factor

Thermal Energy Storage

Sensible heat storage: $Q_{\text{sensible}} = \rho V c_p \Delta T$

Combined latent and sensible heat storage:

$$Q_{\text{total}} = m \left[\bar{c}_{p_{\text{met}}} (T_{\text{met}} - T_{\text{low}}) + \lambda + \bar{c}_{p_{\text{heat}}} (T_{\text{high}} - T_{\text{met}}) \right]$$

Thermochemical energy storage:

$$Q_{\text{thermochemical}} = a_r m \Delta H$$

Where m is the mass of reactant, a_r is the fraction reacted and ΔH is the heat of reaction per unit mass.

Storage materials properties given on pages 51-53.

Thermal conductivities of containment materials

Materials	Thermal conductivity*	
	(W/m K)	(Btu/in hr ft ² °F)
Plastics		
ABS	0.17-0.33	1.2-2.3
Acrylic	0.19-0.43	1.3-3.0
Polypropylene	0.12-0.17	0.8-1.2
Polyethylene (high density)	0.43-0.52	3.0-3.6
Polyethylene (medium density)	0.30-0.42	2.1-2.9
Polyethylene (low density)	0.30	2.1
Polyvinyl chloride	0.13	0.9
Metals		
Aluminum	200	1500
Copper	390	2700
Steel	48	330

*Plastics, a desk-top data bank, 5th Ed. Book A San Diego, CA The International Plastics Selector, Inc., 1980.

As measured by ASTM C-177.

Handbook of Chemistry and Physics, 40th Ed.

Physical properties of some sensible heat storage materials

Storage Medium	Temperature Range, °C	Density (ρ), kg/m ³	Specific Heat (C), J/kg K	Energy Density (ρC), kWh/m ³ K	Thermal Conductivity (W/m K)
Water	0-100	1000	4190	1.16	0.63 at 18°C
Water (10 bar)	0-180	881	4190	1.03	—
50% ethylene glycol-50% water	0-100	1075	3480	0.98	—
Dowtherm A ^a (Dow Chemical Co.)	12-260	867	2200	0.53	0.122 at 260°C
Thermoil 668 ^b (Monsanto Co.)	-9-343	750	2100	0.44	0.106 at 343°C
Draw salt (50NaNO ₃ -50KNO ₃) ^c	220-340	1733	1550	0.75	0.57
Molten salt (51KNO ₃ / 40NaNO ₃ /7NaNO ₂) ^d	142-340	1680	1560	0.72	0.61
Liquid Sodium	100-760	750	1260	0.26	67.5
Cast iron	m.p. (1150-1300)	7200	540	1.08	42.0
Laterite	—	3200	800	0.71	—
Aluminum	m.p. 660	2700	920	0.69	200
Fireclay	—	2100-2600	1000	0.65	1.0-1.5
Rock	—	1600	880	0.39	—

^a Composition in percent by weight.

Note: m.p. = melting point.

Physical properties of latent heat storage materials or PCMs

Storage Medium	Melting Point °C	Latent Heat, kJ/kg	Specific Heat (kJ/kg °C)		Density (kg/m ³)		Energy Density (kWh/m ³ K)	Thermal Conductivity (W/m K)
			Solid	Liquid	Solid	Liquid		
LiClO ₄ · 3H ₂ O	8.1	253	—	—	1730	1530	108	—
Na ₂ SO ₄ · 10H ₂ O (Glauber's Salt)	32.4	251	1.76	3.32	1460	1330	92.7	2.25
Na ₂ S ₂ O ₃ · 5H ₂ O	48	200	1.47	2.39	1730	1665	92.5	0.57
NaCH ₃ COO · 3H ₂ O	58	180	1.90	2.50	1450	1280	64	0.5
Ba(OH) ₂ · 8H ₂ O	78	301	0.67	1.26	2070	1937	162	0.6534
Mg(NO ₃) ₂ · 6H ₂ O	90	161	1.56	3.68	1636	1550	70	0.611
LiNO ₃	232	530	2.02	2.641	2310	1776	261	1.35
LiCO ₃ /K ₂ CO ₃ , (35.65)%	505	345	1.34	1.76	2265	1960	183	—
LiCO ₃ /K ₂ CO ₃ / Na ₂ CO ₃ (32.35-33)%	397	277	1.68	1.63	2300	2140	165	—
n-Tetradecane	5.5	228	—	—	625	771	48	0.150
n-Octadecane	28	244	2.16	—	814	774	52.5	0.150
HDPE (cross-linked)	126	180	2.88	2.51	960	900	45	0.361
Steric acid	70	203	—	2.35	941	547	48	0.172 ^f

^a Composition in percent by weight.

Note: l = liquid

Properties of thermochemical storage media

Reaction	Condition of Reaction		Component (Phase)	Pressure, kPa	Temperature, °C	Volume of Storage, m³	Storage Density, kWh/m³
	Pressure, kPa	Temperature, °C					
MgCO ₃ (s) + 1200 kJ/kg = MgO(s) + CO ₂ (g)	100	427-327	MgCO ₃ (s)	100	20	1500	187
Ca(OH) ₂ (s) + 1415 kJ/kg = CaO(s) + H ₂ O(g)	100	572-402	Ca(OH) ₂ (s)	100	20	1115	345
SO ₂ (g) + 1235 kJ/kg = SO ₃ (g) + O ₂ (g)	100	570-960	SO ₂ (g)	100	45	1900	260
			SO ₃ (g)	630	40	1320	130
			O ₂ (g)	10000	20		


Note: s = solid; f = liquid; g = gas

Photovoltaics Cell Output Characteristics

$$\text{Cell output power across load, } P_L = I_L V = I_L^2 R_L$$

Where I_L is the load circuit current, V is the voltage and R_L is the load resistance

Representative current, voltage, and power outputs of a PV cell




$$\text{Open circuit junction voltage: } V_{oc} = \frac{kT}{e_0} \ln \left(\frac{I_{sc}}{I_0} + 1 \right)$$

Where
 k Boltzmann's constant, (1.381×10^{-23} J/K)
 T cell temperature, (K)
 e_0 electron charge, (1.602×10^{-19} J/V)
 I_{sc} short circuit current
 I_0 reverse saturation current


Voltage at maximum power output, V_m , is found from:

$$\exp \left(\frac{e_0 V_m}{kT} \right) \left(1 + \frac{e_0 V_m}{kT} \right) = 1 + \frac{I_{sc}}{I_0}$$

Effect of illumination and load resistance on PV cell output



Effect of temperature on cell output




Temperature corrections for the cell output are supplied by the manufacturers and are typically of the form:


$$V = V_{\text{ref}} (1 + \beta(T_c - T_{\text{ref}})) \quad \text{and} \quad I = I_{\text{ref}} (1 + \alpha(T_c - T_{\text{ref}}))$$

where the subscript "ref" refers to values at a reference condition and T_c is the actual operating temperature of the cell. α and β are constants provided by the manufacturer. Since α is much smaller than β , power output goes down as the temperature of the cell goes up.


Multiple cell output



Effect of collector tilt and tracking on incident solar radiation



PV Power Configurations



Adapted from [10,13]

57

PV System Design

System Design Suggestions from [13]

- Keep it simple – Complexity lowers reliability and increases maintenance costs.
- Understand system availability – Achieving 99+ % availability with any energy system is expensive.
- Be thorough, but realistic, when estimating the load – A large safety factor can cost you a great deal of money.
- Cross-check weather sources – Errors in solar resource estimates can cause disappointing system performance.
- Know what hardware is available at what cost – Tradeoffs are inevitable. The more you know about hardware, the better decisions you can make. Shop for bargains, talk to dealers, ask questions.
- Install the system carefully – Make each connection as if it had to last 30 years—it does. Use the right tools and technique. The system reliability is no higher than its weakest connection.
- Safety first and last – Don't take shortcuts that might endanger life or property. Comply with local and national building and electrical codes.
- Plan periodic maintenance – PV systems have an enviable record for unattended operation, but no system works forever without some care.
- Calculate the life-cycle cost (LCC) to compare PV systems to alternatives – LCC reflects the complete cost of owning and operating any energy system.

Simplified Average Daily Load Determination from [10]

1. Identify all loads to be connected to the PV system
2. For each load, determine its voltage, current, power and daily operating hours. For some loads, the operation may vary on a daily, monthly or seasonal basis. If so, this must be accounted for in calculating daily averages.
3. Separate ac loads from dc loads.
4. Determine average daily Ah for each load from current and operating hours data. If operating hours differ from day to day during the week, the daily average over the week should be calculated. If average daily operating hours vary

58

- from month to month, then the load calculation may need to be determined for each month.
5. Add up the Ah for the dc loads, being sure all are at the same voltage.
 6. If some dc loads are at a different voltage, which will require a dc to dc converter, then the converter input Ah for these loads needs to account for the conversion efficiency of the converter.
 7. For ac loads, the dc input current to the inverter must be determined and the dc Ah are then determined from the dc input current. The dc input current is determined by equating the ac load power to the dc input power and then dividing by the efficiency of the inverter.
 8. Add the Ah for the dc loads to the Ah for the ac loads, then divide by the wire efficiency factor and the battery efficiency factor to obtain the corrected average daily Ah for the total load.
 9. The total ac power will determine the required size of the inverter. Individual load powers will be needed to determine wire sizing to the loads. Total load current will be compared with total array current when sizing wire from battery to controller.

Storage Estimation: Estimation of the days of battery storage needed for a stand-alone system if no better estimate is available, [10]

$$D_{\text{crit}} = -1.9T_{\text{min}} + 18.3 \quad \text{or}$$


$$D_{\text{non}} = -0.48T_{\text{min}} + 4.58$$

Where:

D_{crit} number of storage days required for critical application
 D_{non} number of storage days required for non-critical application
 T_{min} minimum average daily peak sun hours for selected collector tilt during any month of operation

Note: $T_{\text{min}} \geq 1$ peak sun hours per day

Water Pumping Load Data



Pumping power (W).
$$P = \frac{\rho V g H}{\eta_p}$$

Where:

ρ gravitational acceleration, (9.81 m/s^2)
 H total pumping head, (m)
 H_d dynamic head, (m)
 H_f friction head, (m)
 H_s static head, (m)
 V volumetric flow rate, (m^3/s)
 η_p pump efficiency
 v water velocity at pipe outlet, (m/s)
 ρ_w water density, (997 kg/m^3)

And $H = H_d + H_s$ $H_d = H_f + \frac{v^2}{2g}$

$$H_s = \begin{cases} A + B, \text{ for no draw down} \\ A + B + C, \text{ for water level drawn down a depth } C \end{cases}$$

Representative water pump operating characteristics

Head (m)	Type pump	Wire-to-water efficiency (%)
0-5	Centrifugal	15-25
6-20	Centrifugal with jet	10-20
	Submersible	20-30
21-500	Submersible	30-40
	Jack pump	30-45
>100	Jack pump	15-30

Electrical wire load rating

Resistance and amperage ratings for type THHN insulated wire.

AWG Wire Size	Resistance @ 20°C (Ω/100 ft or Ω/30.5 m)	Maximum Recommended Current (A)	
		15	20
14	0.2525	15	
12	0.1588	20	
10	0.0989	30	
8	0.06282	55	
6	0.03951	75	
4	0.02485	95	
3	0.01970	110	
2	0.01563	130	
1	0.01239	150	
0	0.00983	170	
00	0.00779	195	
000	0.00618	225	
0000	0.00490	260	

Voltage drop due to line resistance:

$$\text{Voltage Drop} = \underbrace{\text{Current}}_{\left(\frac{V}{100 \text{ ft}(30.5 \text{ m})} \right)} \times \underbrace{\text{Wire Resistance}}_{\left(\frac{\Omega}{100 \text{ ft}(30.5 \text{ m})} \right)}$$

Water Heating Systems


General design configurations and guidelines. Collector performance information is available on page 46, system evaluation and sizing can be estimated using the f-chart method, beginning page 66.

Integrated collector and storage or batch systems.

Storage tank integrated with collector or storage tank itself is the solar absorber. Circulation is passive through natural convection.

- ⊕ Simple, no moving parts, long lifetime, little maintenance.
- ⊖ Small systems only, limited freeze protection

Natural circulation (thermosyphon loop) system.



Circulation is caused by the difference in density, ρ , between the hot water in the collector and cooler water exiting the storage tank. To estimate circulation rate, compute the flow pressure drop, ΔP_{flow} :

$$\Delta P_{flow} = \rho_{storage} gH - [\rho_{collector ave} gL + \rho_{col out} g(H-L)]$$


Flow velocity, V , can then be determined by knowing K_{loop} , the loop sum of the component velocity loss factors:

$$V = \sqrt{\frac{\Delta P_{flow}}{\rho_{loop ave} K_{loop}}}$$

Natural circulation (thermosyphon loop) system.

- ☛ Simple, moderate sizes, long lifetime in areas with little chance of freezing
- ☛ Tank must be mounted above collectors, freeze protection difficult.

Forced circulation open loop system.



Fluid is actively pumped through the collector, and the reservoir is vented so pressure is maintained at atmospheric. Drainback operation is possible for freeze and stagnation protection.


- ☛ Simple, increased capacity compared to passive circulation.
- ☛ Freeze protection not as reliable as closed loop drainback, pump must supply entire head from storage tank to collector.

Forced circulation closed loop pressurized system.


Fluid loop is not vented so pumping power is limited to the flow resistance of the piping. Since fluid stays in the collector, glycol solutions are used for freeze protection.

- ☛ Good freeze protection in cold climates, reduced pumping power, can be used when drainback is not possible.
- ☛ Complex system, fluid expansion must be accommodated, no stagnation protection.

Forced circulation closed loop pressurized system.



Forced circulation closed loop drainback system.



Fluid in collectors is allowed to drain into a reservoir located near the collectors but in a non-freezing location.

- ☛ Reliable freeze and stagnation protection, pure water working fluid can be used, pumping head reduced with elevated drainback tank.
- ☛ Piping must have sufficient slope for drainback

Hot Water Load Data

Energy requirement for service water heating.

$$q_{hw} = \rho_w Q c_{pw} (T_d - T_s)$$

Where:

c_{pw}	specific heat of water, 4.18 kJ/kg-K
Q_{hw}	water heating energy requirement
Q	volumetric water flow rate
T_d	water delivery temperature
T_s	water supply temperature
ρ_w	water density, 997 kg/m³

Guidelines for service hot water demand rates

Usage type	Demand per person	
	btu/h/day	gal/h/day
Retail store	2.8	0.75
Elementary school	5.7	1.5
Multifamily residence	76.0	20.0
Single-family residence	76.0	20.0
Office building	11.0	3.0

Building Heat Load Data

Given the overall building loss coefficient, UA (W/C), the degree-day method can be used to estimate the heat demand,

$$Q_n \text{ for day } n: Q_n = \overline{UA} (T_n - \bar{T}) \quad \text{with} \quad T_n = T_i - \frac{q_i}{UA}$$

Where T_i is the interior temperature, q_i is the interior heat generation, and \bar{T} (daily average temp) can be estimated from location-specific maximum and minimum temperature data:

$$\bar{T} = \frac{T_{max} + T_{min}}{2}$$

Note: For a thorough treatment of heating loads, the reader is referred to the ASHRAE Handbook, Fundamentals, [1].

Heating System Evaluation and Sizing

Procedure for estimating the performance and/or size of standard solar heating applications using f-chart. The f-chart method computes the solar-supplied fraction, f_s , of thermal energy for liquid and air based heating systems.

Note: The procedures outlined here are for estimation purposes only, detailed calculations of the system thermal performance and solar collection are needed to ensure satisfactory system performance.

The f-chart method assumes standard system configurations, Figs. f-1 and f-2, and applies only to these systems, with limited variations. For example, the collector-to-storage heat exchanger in the liquid based system (Fig. f-1) may be eliminated ($F_{hx} = 1$), or for the air-based system (Fig. f-2) the two-tank domestic water heater may be reconfigured as a one tank system. Furthermore, f-chart is applicable to solar heating systems where the minimum temperature for energy delivery is approximately 20°C.

System parameter ranges used to compile the f-chart results

Collector transmissivity-absorbtivity, $(\tau\alpha)_c$	0.6-0.9
Collector heat removal factor-area, F_{RA_c}	5-120 m^2
Collector heat loss coefficient, U_c	2.1-8.3 $W/m^2 \cdot ^\circ C$
Collector tilt angle, β	30°-90°
Overall building loss coefficient, UA	83-667 W/C

Begin with:

- **Monthly heating load;** for information regarding water heating and building heating loads refer to page 65
- **Monthly solar radiation totals for site-specific collector-plane;** can be obtained from internet sources, page 83, or for simple geometries, computed with the procedure beginning on page 32.
- **Collector performance parameters $F_{R\tau\alpha}$ and F_{RU} ;** can be obtained from the manufacturer or representative values for non-concentrating collectors are given on page 46.
- **Solar system design parameters;** this includes the collector area, working fluid, fluid flow rate per unit area of collector, storage capacity, and heat exchanger performance. The standard configurations assumed with this method are shown in Figs. f-1 and f-2 for water and air based systems respectively.

Procedure begins on page 68




Figure f-1. Schematic for a standard liquid-based solar heating system. Note certain deviations from this configuration can be handled by the f-chart method.




Figure f-2. Schematic for a standard air-based solar heating system. Note certain deviations from this configuration can be handled by the f-chart method.

Procedure:

1. Compute the loss parameter, P_L .

$$P_L = \frac{A_c F_{ch} F_{ex} \Delta t (T_R - \bar{T}_a)}{L}$$

Where A_c is the net collector area (m^2), F_{ch} is the collector loop heat-exchanger factor (= 1 if no heat exchanger), Δt is the number of seconds per month, T_R is a reference temperature of $100^\circ C$, \bar{T}_a is the monthly average ambient temperature ($^\circ C$), and L is the total monthly heating load ($J/month$)

2. Compute the solar parameter, P_s :

$$P_s = \frac{A_c \bar{I}_c F_{ch} F_{ex} (\tau\alpha)_n}{L} \left(\frac{F_R(\bar{\tau}\alpha)}{F_R(\tau\alpha)_n} \right)$$

Where \bar{I}_c is the total monthly collector-plane insolation ($J/m^2-month$) and

$$\left(\frac{F_R(\bar{\tau}\alpha)}{F_R(\tau\alpha)_n} \right) = 0.95 \text{ for collectors tilted within } \pm 20^\circ \text{ of the local latitude}$$

3. Compute modified parameters based on deviations from standard systems. See Table f-1 for liquid based systems, Table f-2 for air based systems and/or the modification for water heating-only (below)

Water-heating-only loss parameter modification:

$$P_L = \frac{A_c F_{ch} F_{ex} \Delta t (11.6 + 1.18T_{w0} + 3.86T_{w1} - 2.32\bar{T}_a)}{L}$$

4. Compute the solar supplied fraction, f_s , of the monthly heating load. Read f_s from the appropriate figure, (Fig f-3 liquid/ Fig f-4 air) or use the associated expressions (below)

Liquid based systems:

$$f_s = 1.029P_s - 0.065P_L - 0.245P_s^2 + 0.0018P_L^2 + 0.0215P_s^3$$

Air based systems:

$$f_s = 1.040P_s - 0.065P_L - 0.159P_s^2 + 0.00187P_L^2 - 0.0095P_s^3$$

For the conditions:

$$0 \leq P_s \leq 30; 0 \leq P_L \leq 18.0; 0 \leq f_s \leq 1.0 \text{ and } P_s > P_L/12 \text{ Liquid}$$

$$P_s > 0.07P_L \text{ Air}$$

Table f-1. Liquid based system nominal values and modifying groups

Parameter	Nominal value	Modified parameter ^a
Flow rate (m^3/s)	0.0128 liters H ₂ O equivalent/ sec · m ²	$P_t = P_{t,nom} \frac{F_t F_k}{(F_{t,nom} F_{k,nom})}$ (5.23)
		$P_t = P_{t,nom} \frac{F_t}{(F_{t,nom} F_{k,nom})}$ (5.24)
Storage volume (water) $V_s = \left(\frac{M}{\rho_s}\right)_s$	75 liters H ₂ O/m ²	$P_t = P_{t,nom} \left(\frac{V_s}{75}\right)^{0.25}$ (5.25)
Load heat exchanger $\frac{\epsilon_{min} \rho_{air}}{Q_L}$	2.0	$P_t = P_{t,nom} \left[0.103 + 0.65 \exp \left(-0.139 \cdot \frac{Q_L}{\epsilon_{min} \rho_{air}} \right) \right]$ (5.26)

^aTable prepared from data and equations presented in [2,8]

^bMultiply basic definition of P_t and $P_{t,nom}$ in points 1 and 2 by factor for nonnominal group values: ($F_{t,nom} F_{k,nom}$) refers to values of $F_{t,nom} F_{k,nom}$ at collector rating or test conditions.

In liquid systems the correction for flow rate is small and can usually be ignored if variation is no more than 50 percent below the nominal value.

$\epsilon_{min} \rho_{air}$ is the minimum fluid capacitance rate, usually that of air for the load heat exchanger. Q_L is the heat load per unit temperature difference between inside and outside of the heating.

Table f-2. Air based system nominal values and modifying factors

Parameter	Nominal value ^a	Loss parameter multiplier ^b
Storage capacity V_s	0.25 m ³ /m ²	$\left(\frac{0.25}{V_s}\right)^{0.25}$
Fluid volumetric flow rate Q_t	10 Liters/sec · m ²	$\left(\frac{Q_t}{10}\right)^{0.25}$

^aAdapted from [2,8]

^bBased on net collector area; fluid volume at standard atmosphere conditions.




Figure f-3. f-chart for liquid based solar heating systems, [8]





Figure f-4. f-chart for air based solar heating systems, [8].

Daylighting

General design guidelines, from [7]

- Orient building to maximize daylighting. Long axis running east-west preferred.
- Maximize south glazing, minimize east and west facing glass. A south-facing aperture is the only orientation that, on an annual basis, balances typical thermal needs and lighting requirements with available radiation.
- Optimally size overhangs on south-facing glazing to harvest daylighting, reduce summer heat gain, and permit the passive collection of solar thermal in winter.
- Select the right glazing. Where windows are used specifically for daylighting, clear glass has an advantage over glazing with a low-E coating due to the coating's typical 10% to 30% reduction in visible light transmission.
- Eliminate direct beam radiation. Use baffles to block direct beam radiation, diffuse light, and reduce glare.
- Account for shading from adjacent buildings and trees and consider the reflectance from adjacent surfaces.
- Use light colored roofing in front of monitors and select light colors for interior finishes to reflect in additional light and enhance distribution throughout the room.

Daylighting Comparison



Selection Criteria for Daylighting Strategies.

Design Criteria	View Windows (DL1)	High Sidelight W/ Light shelf (DL2 & DL3)	Wall Wash Toplighting (DL4)	Central & Patterned Toplighting (DL5 & DL6)	Linear Toplighting (DL7)	Tubular Skylights (DL8)
Uniform Light Distribution	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○
Low Glare	○	● ●	○ ○	○ ○	○ ○	○ ○
Reduced Energy Costs	○	● ●	● ●	● ●	● ●	● ●
Cost Effectiveness	● ●	● ●	● ●	● ●	● ●	● ●
Safety/Security Concerns	○ ○	○ ○	● ●	● ●	● ●	● ●
Low Maintenance	○ ○	● ●	● ●	● ●	● ●	● ●

Legend: ● Extremely good application ● Good application ○ Poor application ○○ Extremely poor application ○ Depends on space layout and number and distribution of daylight apertures ○○ Mixed benefits

Reprinted from [14]

Note: The configuration of the view window is with no controls, daylighting performance can be improved with appropriate measures, overhangs, shades, etc. Additionally, the benefit of providing a direct visual connection to the outdoors is not considered in this comparison

Daylighting Design

Lumen method for estimating workplane illuminance level with sidelighting and skylighting.

Sidelighting with vertical windows:

Sidelighting with vertical windows:




Figure d-1. Location of illumination points within the room (along the centerline of window) determined by lumen method of sidelighting, [6]

1. Determine the total sky illuminance entering the window, E_{sw} . Compute the solar altitude and azimuth angle for the desired latitude, date, and time of day, page 6. Compute the sun-window normal azimuth angle difference

using: $a_{sw} = |a_s - a_w|$ Using the figures for vertical surfaces on page 74, determine the direct sun illuminance, $E_{v,sun}$, and the direct sky illuminance, $E_{v,sky}$, for the appropriate sky conditions. Then: $E_{sw} = E_{v,sun} + E_{v,sky}$.

2. Determine the reflected ground illuminance entering the window, E_{gw} . Read values of direct sun and sky illuminance for a horizontal surface, $E_{h,sun}$ and $E_{h,sky}$, page 74. For uniformly reflective ground surfaces extending from the window outward to the horizon, the illuminance on the window from ground reflection, E_{gw} , can be determined

with: $E_{gw} = \rho(E_{h,sun} + E_{h,sky})/2$ Where typical reflectivity values, ρ , come from the table on page 36.

3. Determine the net window transmittance, τ .

$$\tau = TR_a T_c LLF$$
 where T is the glazing transmittance, R_a is the ratio of net to gross window areas and T_c is the transmittance of any light-controlling devices. Light loss factor values, LLF, can be taken from table d-2.

Sidelighting with vertical windows:

- 4 Compute the work plane illuminances for the geometry shown on page 72 $E_{wp} = \tau(E_{sw} CU_{sky} + E_{gw} CU_g)$ where the coefficients of utilization for the sky component, CU_{sky} , are taken from Table d-3, page 75-76, a-e depending on the ratio of E_{sky}/E_{hsky} . CU_g values are read from table d-3, f.


Table d-1. Glass transmittances

Glass	Thickness (in.)	τ
Clear	1/8	.89
Clear	1/16	.88
Clear	1/4	.87
Clear	1/16	.86
Grey	1/8	.61
Grey	1/16	.51
Grey	1/4	.44
Grey	1/16	.35
Bronze	1/8	.68
Bronze	1/16	.59
Bronze	1/4	.52
Bronze	1/16	.44
Thermopane	1/8	.80
Thermopane	1/16	.79
Thermopane	1/4	.77

Murdoch [11]

Table d-2 Light loss factors, [6].

Locations	Light Loss Factor Glazing Position		
	Vertical	Sloped	Horizontal
Clean Areas	0.9	0.8	0.7
Industrial Areas	0.8	0.7	0.6
Very Dirty Areas	0.7	0.6	0.5



Sidelighting with vertical windows:

Table d-3. Coefficients of utilization for lumen method of sidelighting (window without blinds). [6]

- b CUsky for (Ew/Eh)sky = 1 00

c. Cl_{sky} for (E_v/E_n)_{sky} = 1/25

Sidelighting with vertical windows:

Table d-3. Coefficients of utilization for lumen method of sidelighting (window without blinds), [6].

4

卷之三

Lumen method for skylighting:

- Determine the total sky illuminance entering the skylight.** Compute the solar altitude angle for the desired latitude, date, and time of day, page 6. Determine the total horizontal skylight illuminance, E_H , (direct sun plus sky illuminance) using the appropriate horizontal surface data in Figure d-2, page 74.
- Determine the net skylight transmittance, T_n .** The flat plate transmittances, T_F , for several plastic materials are provided in Table d-3 below. For domed skylights, the effective dome transmittance, T_D , can be computed using:

$T_D = 1.25T_F (1.18 - 0.416T_F)$ For double-domed skylights, the individual transmittances can be combined

$$\text{using: } T_D = \frac{T_1 T_2}{T_1 T_2 - T_1 T_2} \quad \text{Also determine the light loss factor, LLF from Table d-2, page 73. Compute the well cavity ratio for the skylight well with: } WCR = \frac{5h(w+1)}{wl}$$

Using Figure d-3, page 78, determine the skylight well efficiency, N_w . Compute the net skylight transmittance, T_n , using: $T_n = T_D N_w R_A T_c LLF$ where R_A is the ratio of net to gross skylight areas and T_c is the transmittance of any light-controlling devices.

Table d-3 Flat-plate plastic material transmittance for skylights
Source: Murdoch[11]

Type	Thickness (in.)	Transmittance
Transparent	1/16	.92
Dense translucent	1/8	.32
Dense translucent	3/16	.24
Medium translucent	1/4	.56
Medium translucent	3/8	.52
Light translucent	1/2	.72
Light translucent	1/16	.68

Lumen method for skylighting:




Figure d-3. Efficiency of well, N_w , versus well cavity ratio, [6].

- Compute the room coefficient of utilization, CU.** For office and warehouse interiors CU can be estimated with:

$$CU = \frac{1}{1 + A(SCR)^B} \quad \text{for } SCR < 8 \quad \text{where}$$

$A=0.0288$, $B=1.560$ for offices (typical reflectance: ceiling 0.75, wall 0.5, floor 0.3) and $A=0.0995$, $B=1.087$ for warehouses (typical reflectance: ceiling 0.5, wall 0.3, floor 0.2). The room cavity ratio is given by


$$SCR = \frac{5h_c(l+w)}{lw} \quad \text{with } h_c \text{ being the ceiling height}$$

above the work plane and l and w being the room length and width, respectively.

- Compute the illuminance at the work plane, E_{WP} .**

$$E_{WP} = E_H T_n (CU) \left(\frac{A_T}{A_{WP}} \right) \quad \text{where } A_T \text{ is the total gross area of the skylights (number of skylights times the skylight gross area), and } A_{WP} \text{ is the work plane area (typically room length times width). Note that it is possible to fix the } E_{WP} \text{ at some desired value and determine the skylight area required, however, due to their dependence on } A_T, \text{ the factors } N_w \text{ and } R_A \text{ (step 2) should be recalculated.}$$

Solar Dryer Configurations



Safe storage moisture for aerated good quality grain, [15]

Grain	Maximum safe moisture content
Shelled corn and sorghum	
To be sold as #2 grain or equiv. by spring	15.5%
To be stored up to 1 year	14%
To be stored more than 1 year	13%
Soybeans	
To be sold by spring	14%
To be stored up to 1 year	12%
Wheat	13%
Small grain (oats, barley, etc.)	13%
Sunflowers	9%

Life Cycle Costing

Life Cycle Cost (LCC) is an economic measure that reflects the benefits accrued by solar usage throughout the lifetime of a solar-powered system. This is opposed to a simple initial cost comparison, which does not include lifetime energy consumption and, therefore, typically favors non-renewable alternatives.

LCC is the sum of the present worth (pw) values of all of the expenses associated with the system over its expected lifetime:

$$LCC = C + M_{pw} + E_{pw} + R_{pw} - S_{pw}$$

Where:

C capital cost of a project which includes the initial capital expense for equipment, the system design, engineering, and installation. This cost is always considered as a single payment occurring in the initial year of the project, regardless of how the project is financed.

M maintenance is the sum of all yearly scheduled operation and maintenance (O&M) costs. Fuel or equipment replacement costs are not included.

E energy cost is the sum of the yearly fuel or electricity cost for the system.

R replacement cost is the sum of all repair and equipment replacement cost anticipated over the life of the system.

S salvage value of a system is its net worth in the final year of the life-cycle period. It is common practice to assign a salvage value of 20% of original cost for mechanical equipment that can be moved.

Computation of the present worth of future expenditures.

1. The single present worth (P) of a future sum of money (F) in a given year (N) at a given investment rate (D) and inflation rate (i) is:

$$P = FX^N \quad \text{with} \quad X = \left(\frac{1+i}{1+D} \right)$$

2. The uniform present worth (P) of an annual sum (A) received over a period of years (N) at a given investment rate (D) and inflation rate (I) is.

$$P = A \left(1 - X^N \right) / \left(X^I - 1 \right)$$

Example: Compare the life cycle cost for a photovoltaic power supply with battery storage and a gasoline engine-generator alternative (systems specified below)

Given: Life cycle period: 20 years
 Investment rate: 7%
 General inflation: 3%
 Fuel inflation: 4%

Solution: Begin with system designs for each alternative, making sure that each system provides equivalent performance, for example: power output, reliability, lifetime, etc. Using a detailed cost estimate (sample below), the present worth of each component is determined. For future one-time expenditures, (e.g. battery replacement, generator rebuild) point 1 above can be used. For costs repeating on an annual basis (e.g. maintenance, generator fuel) point 2 is used. Note the use of a separate fuel inflation rate for fuel expenses. The present worth values are then summed (less salvage) to give the LCC.

PV System

Item	Initial Cost (\$)	Present Worth (\$)
1. Capital		
Array	2500	2500
Controller	300	300
Batteries	900	900
Installation	700	700
2. Maintenance		
Annual Inspection (per year)	75	1030
3. Energy		
None		

continued

Item	Initial Cost (\$)	Present Worth (\$)
4. Replacement		
Battery bank @ yr 5	900	744
Battery bank @ yr. 10	900	615
Battery bank @ yr. 15	900	509
5. Salvage		
20% of original equipment cost	740	(346)
LCC: (Items 1 + 2 + 3 + 4 - 5)		\$6,952

Engine-generator System

Item	Initial Cost (\$)	Present Worth (\$)
1. Capital		
Generator	400	400
Installation	300	300
2. Maintenance		
Tune-up (per year)	150	2060
Annual Inspection (per year)	75	1030
3. Energy		
Annual fuel cost (4% fuel inflation rate)	375	5640
4. Replacement		
Gen rebuild @ yr. 5	250	207
Gen rebuild @ yr. 10	250	171
Gen. rebuild @ yr 15	250	142
5. Salvage		
20% of original equipment cost	80	(38)
LCC: (Items 1 + 2 + 3 + 4 - 5)		\$9,912

References

Internet sources of data

Solar Resource Data

World radiation data center (WRDC) online archive, Russian Federal Service for Hydrometeorology and Environmental Monitoring; 1964-1993 data <http://wrdc.mgo.nrel.gov/>
1994-present data <http://wrdc.mgo.rssi.ru/>

Surface meteorology and solar energy, National Aeronautics and Space Administration, USA; <http://eosweb.larc.nasa.gov/sse>

Solar radiation resource information, National Renewable Energy Laboratory, USA, <http://rredc.nrel.gov/solar>

Climatic Data

World climatic data, World Weather Information Service; <http://www.worldweather.org>

U. S. climate data, National Oceanic and Atmospheric Administration, USA; <http://www.noaa.gov/climate.html>

Cited References

1. ASHRAE 2001 *2001 ASHRAE Handbook, Fundamentals*. Atlanta American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
2. Duffie, J. A. and Beckman, W. A. 1991 *Solar Engineering of Thermal Processes* 2nd ed. New York John Wiley & Sons
3. Building Technologies Program, Lawrence Berkeley National Lab 1997 *Tips for Daylighting with Windows* Berkeley Lawrence Berkeley National Lab
4. Collares-Pereira and Rabl, A. 1979 Simple Procedure for Predicting Long Term Average Performance of Nonconcentrating and of Concentrating Solar Collectors *Solar Energy*, Vol. 23, pg. 235-254
5. Goswami, D. Y., Kreith, F., and Kreider, J. 2000 *Principles of Solar Engineering*, 2nd ed. Philadelphia: Taylor & Francis
6. IESNA 2000 *The IESNA Lighting Handbook* New York Illumination Engineering Society of North America Reprinted with permission from the IESNA Lighting Handbook, 9th Edition, courtesy of the Illuminating Engineering Society of North America
7. Innovative Design, Inc. 2004 *Guide for Daylighting Schools* Raleigh, NC: Innovative Design, Inc.
8. Klein, S. A. 1976 *A Design Procedure for Solar Heating Systems*, Ph.D. dissertation, Univ. of Wisconsin, Madison For an approach similar to the f-chart for other solar-thermal systems operating above a minimum temperature above that for space-heating (~20°C), see Klein, S. A. and Beckman, W. A. 1977 A General Design Method for Closed Loop Solar Energy Systems *Proc 1977 ISES Meeting*
9. Lof, G. O. G. and Tybout, R. A. 1972. Model for Optimizing Solar Heating Design ASME Paper 72-WASOL-8
10. Messenger, R. and Ventre, J. 2000 *Photovoltaic Systems Engineering* Boca Raton, FL: CRC Press
11. Murdoch, J. B. 1985 *Illumination Engineering From Edison's Lamp to the Laser*. New York: Macmillan Publishing Co.
12. Norton, B. 1992 *Solar Energy Thermal Technology* London: Springer-Verlag
13. Post, H. N. and Risser, V. V. 1995. *Stand-Alone Photovoltaic Systems—A Handbook of Recommended Design Practices*. Albuquerque Sandia National Lab Report SAND-87-7023
14. U.S. Department of Energy 2002. *National Best Practices Manual for Building High Performance Schools*. Publication DOE/GO-102002-1610
15. Midwest Plan Service 1980 *Low Temperature and Solar Grain Drying Handbook* Ames, IA: Iowa State University

Units and Conversion Factors

Fundamental SI units

Quantity	Name of unit	Symbol
Length	Meter	m
Mass	Kilogram	kg
Time	Second	sec
Electric current	Ampere	A
Thermodynamic temperature	Kelvin	K
Luminous intensity	Candela	cd
Amount of a substance	Mole	mol

Derived SI units

Quantity	Name of unit	Symbol
Acceleration	Meters per second squared	m/sec ²
Area	Square meters	m ²
Density	Kilogram per cubic meter	kg/m ³
Dynamic viscosity	Newton-second per square meter	N · sec/m ²
Force	Newton (= 1 kg · m/sec ²)	N
Frequency	Hertz	Hz
Kinematic viscosity	Square meter per second	m ² /sec
Plane angle	Radian	rad
Potential difference	Volt	V
Power	Watt (= 1 J/sec)	W
Pressure	Pascal (= 1 N/m ²)	Pa
Radiant intensity	Watts per steradian	W/sr
Solid angle	Steradian	sr
Specific heat	Joules per kilogram-Kelvin	J/kg · K
Thermal conductivity	Watts per meter-Kelvin	W/m · K
Velocity	Meters per second	m/sec
Volume	Cubic meter	m ³
Work, energy, heat	Joule (= 1 N · m)	J

Fundamental constants

Quantity	Symbol	Value
Avogadro constant	N	6.022169×10^{26} kmol ⁻¹
Boltzmann constant	k	1.380622×10^{-23} J/K
First radiation constant	C ₁ = $2\pi hc^2$	3.741844×10^{-16} W · m ²
Gas constant	R	8.31434×10^3 J/kmol · K
Planck constant	h	6.626196×10^{-34} J · sec
Second radiation constant	C ₂ = hc/k	$1.438833 \times 10^{-2} \text{ m} \cdot \text{K}$
Speed of light in a vacuum	c	2.997925×10^8 m/sec
Stefan-Boltzmann constant	σ	5.66961×10^{-8} W/m ² · K ⁴

Conversion Factors

Physical quantity	Symbol	Conversion factor
Area	A	1 ft ² = 0.0929 m ² 1 acre = 43,560 ft ² = 4047 m ² 1 hectare = 10,000 m ² 1 square mile = 640 acres
Density	ρ	1 lb./ft ³ = 16.018 kg/m ³ 1 Btu = 1055 J
Heat, energy, or work	Q or W	1 kWh = 3.6 MJ 1 Therm = 105,506 MJ 1 cal = 4.186 J 1 ft · lb = 1.3558 J 1 lb = 4.448 N
Force	F	1 Btu/hr = 0.2931 W
Heat flow rate, Refrigeration	q	1 ton (refrigeration) = 3.517 kW 1 Btu/sec = 1055.1 W
Heat flux	q/A	1 Btu/hr · ft ² = 3.1525 W/m ²
Heat-transfer coefficient	h	1 Btu/hr · ft ² · F = 5.678 W/m ² · K
Length	L	1 ft = 0.3048 m 1 in = 2.54 cm 1 mi = 1.6093 km
Mass	m	1 lb _m = 0.4536 kg 1 ton = 2240 lbm 1 tonne (metric) = 1000 kg 1 lb _m /hr = 0.000126 kg/sec
Mass flow rate	\dot{m}	1 hp = 745.7 W 1 kW = 3415 Btu/hr
Power	W	1 ft · lb/sec = 1.3558 W 1 Btu/hr = 0.293 W
Pressure	P	1 lb/in ² (psi) = 6894.8 Pa (N/m ²) 1 atm = 3.386 Pa
Radiation	I	1 atm = 101,325 Pa (N/m ²) = 14.696 psi 1 langley = 41,660 J/m ²
Specific heat capacity	c	1 langley/min = 697.4 W/m ² 1 Btu/lb _m · °F = 4187 J/kg · K
Internal energy or enthalpy	e or h	1 Btu/lb _m = 2326.0 J/kg 1 cal/g = 4184 J/kg
Temperature	T	T(°R) = (9/5)T(K) T(°F) = [T(°C)(9/5)] + 32 T(°F) = T(K) - 273.15(9/5) + 32
Thermal conductivity	k	1 Btu/hr · ft · °F = 1.731 W/m · K
Thermal resistance	R _{th}	1 hr · °F/Btu = 1.8958 K/W
Velocity	V	1 ft/sec = 0.3048 m/sec 1 mi/hr = 0.44703 m/sec
Viscosity, dynamic	μ	1 lb _l /ft · sec = 1.448 N · sec/m ² 1 cP = 0.00100 N · sec/m ²
Viscosity, kinematic	ν	1 ft ² /sec = 0.09029 m ² /sec 1 ft/hr = 2.581×10^{-5} m ² /sec
Volume	V	1 ft ³ = 0.02832 m ³ = 28.32 liters 1 barrel = 42 gal (U.S.) 1 gal (U.S. lit) = 3.785 liters 1 gal (U.K.) = 4.546 liters
Volumetric flow rate	\dot{V}	1 ft/min (cfm) = 0.000472 m ³ /sec 1 gal/min (GPM) = 0.0631 l/sec

The History of ISES

1954	ISES has its origin in Phoenix, Arizona, USA. A group of industrial, financial and agricultural leaders establishes the "Association for Applied Solar Energy" (AFASE) as a non-profit organization.	
1955	The first two important meetings are held in Tucson and Phoenix, USA which attract more than 1000 scientists, engineers and government officials from 36 different countries	
1956	The association establishes its first scientific publication "the sun at work"	
1957	The first issue of "The Journal of Solar Energy, Science and Engineering" is published	
1963	Dedicated solar scientists decide that radical changes are required for the operation and goals of the society. Through the reorganization within the framework of its original concept the name is changed to "The Solar Energy Society". Accreditation of the society at the United Nations Economic & Social Council (ECOSOC)	
1964	The name of the journal is changed to "Solar Energy – The Journal of Solar Energy Science and Technology". Prof Farrington Daniels is elected President and in his honor the 'Farrington Daniels Award' is established in 1975. The award signifies outstanding intellectual leadership in the field of renewable energy	
1970	Relocation of the international headquarters office to Melbourne, Australia. First international conference outside the USA is held in Melbourne, Australia	
1971	The name of the society is changed to "International Solar Energy Society"	
1976	The first issue of the ISES magazine "SunWorld" is published	
1979	ISES celebrates its Silver Jubilee at the Solar World Congress in Atlanta, USA	
1980	The 'Achievement through Action Award' in memory of Christopher A Weeks is set up. A substantial cash prize honors contributions for practical use or new concepts	
1989	ISES introduces the "Section Sponsorship Programme" in which individuals and sections have the opportunity to sponsor sections from developing countries	
1992	Accepted by the United Nations as a non-governmental organization (NGO) in consultative status, ISES actively participates in the United Nations Conference on Environment and Development (UNCED), held in Rio de Janeiro, Brazil	
1994	ISES coordinates the second meeting of the United Nations Commission on Sustainable Development (CSD) in New York to discuss issues of sustainable development and the interlinkages to renewable energy technologies	
1995	The Headquarters office moves from Melbourne, Australia to Freiburg, Germany. The Headquarters becomes a focal point for international projects	
2000	Launch of new official ISES magazine "Refocus" (Renewable Energy Focus)	
2002	The first woman elected as President. Prof Anne Grete Hestnes takes over office on January 1st, 2002	
2005	ISES participates in the World Summit on Sustainable Development (WSSD) in Johannesburg, South Africa. Established on December 24, 1954 the society celebrates its Golden Jubilee at the Solar World Congress in Orlando, Florida, USA in August 2005.	